



2019/20 REPORT FOR TESTING LEAD CONTENT IN DRINKING WATER OF SCHOOL FACILITIES

School District Information		Health Authority (HA) Information	
SD No.	61	Region	Victoria Island Health Authority
SD Name	Greater Victoria	Contact Name	Stacey Sowa
SD Contact Name:	Justin Taylor	Contact Phone	stacey.sowa@viha.ca
SD Contact Phone:		Report Submitted to HA	Yes
Report Date	3/27/2020	Report Submission Date	3/27/2020

[Click here to access the School Master List for Facility Names and Facility Codes](#)

SCHOOL FACILITY INFORMATION				TEST INFORMATION					MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN			ADDITIONAL INFORMATION		
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period
61	06161062	Arbutus Global Middle School	1969	Sep/17	2	Water Fountain	Corridor-1079	0.001	No	30 Sec flush before use until filter can	Information is provided to School staff	None.	Sep/20	30-Mar-20
61	06161062	Arbutus Global Middle School	1969	Nov/19	1	Sink	Staff-1004	0.001	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Nov/20	30/Mar/20
61	06161062	Arbutus Global Middle School	1969	Aug/19	1	Water Fountain	Corridor-1040	0.004	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Aug/20	30/Mar/20
61	06161062	Arbutus Global Middle School	1969	Oct/19	2	Sink	Foods-1035	0.004	No	30 Sec flush before use until filter can	Information is provided to School staff	None.	Oct/20	30/Mar/20
61	06161062	Arbutus Global Middle School	1969	Oct/19	2	Sink	Foods-1035	0.000	No	30 Sec flush before use until filter can	Information is provided to School staff	None.	Oct/20	30/Mar/20
61	06161062	Arbutus Global Middle School	1969	Oct/19	2	Sink	Foods-1035	0.001	No	30 Sec flush before use until filter can	Information is provided to School staff	None.	Oct/20	30/Mar/20
61	06161062	Arbutus Global Middle School	1969	Oct/19	1	Sink	Foods-1035	0.004	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Oct/20	30/Mar/20
61	06161062	Arbutus Global Middle School	1969	Oct/19	2	Sink	Foods-1035	0.001	No	30 Sec flush before use until filter can	Information is provided to School staff	None.	Oct/20	30/Mar/20
61	06161062	Arbutus Global Middle School	1969	Oct/19	2	Sink	Foods-1035	0.000	No	30 Sec flush before use until filter can	Information is provided to School staff	None.	Oct/20	30/Mar/20
61	06161062	Arbutus Global Middle School	1969	Nov/19	1	Water Filling Station	Corridor-1044	0.002	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Nov/20	30/Mar/20
61	06161062	Arbutus Global Middle School	1969	Nov/19	1	Water Fountain	Changeroom - 0002	0.003	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Nov/20	30/Mar/20
61	06161062	Arbutus Global Middle School	1969	Sep/17	2	Water Fountain	Changeroom - 0008	0.002	No	30 Sec flush before use until filter can	Information is provided to School staff	None.	Sep/20	30/Mar/20
61	06161062	Arbutus Global Middle School	1969	Oct/19	2	Sink	Foods-1035	0.000	No	30 Sec flush before use until filter can	Information is provided to School staff	None.	Oct/20	30/Mar/20
61	06161062	Arbutus Global Middle School	1969	Oct/19	2	Sink	Foods-1035	0.001	No	30 Sec flush before use until filter can	Information is provided to School staff	None.	Oct/20	30/Mar/20
61	06161062	Arbutus Global Middle School	1975	Aug/19	1	Sink	Kitchen-1060	0.063	Yes	Sink has been shut off to and labeled c	Information is provided to School staff	None.	Aug/20	30/Mar/20
61	06161062	Arbutus Global Middle School	1969	Oct/19	2	Sink	Foods-1035	0.003	No	30 Sec flush before use until filter can	Information is provided to School staff	None.	Oct/20	30/Mar/20
61	06161051	Braefoot Elementary	1971	Sep/17	2	Sink	Kitchen-1037	0.001	No	30 Sec flush before use until filter can	Information is provided to School staff	None.	Sep/20	30-Mar-20
61	06161051	Braefoot Elementary	1971	May/19	1	Water Fountain	Corridor-1043	0.004	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	May/20	30/Mar/20
61	06161051	Braefoot Elementary	1971	Sep/17	2	Water Filling Station	Corridor - 1043	0.002	No	30 Sec flush before use until filter can	Information is provided to School staff	None.	Sep/20	30/Mar/20
61	06161051	Braefoot Elementary	1970	May/19	1	Sink	Staff-1024	0.012	Yes	School is under seismic upgrade and l	Information is provided to School staff	None.	May/20	30/Mar/20
61	06161051	Braefoot Elementary	1970	May/19	1	Water Filling Station	Corridor-1049	0.002	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Aug/20	30/Mar/20
61	06161051	Braefoot Elementary	1970	May/19	1	Water Filling Station	Corridor-2005	0.005	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	May/20	30/Mar/20
61	06161051	Braefoot Elementary	1970	May/19	1	Sink	Class-2006	0.004	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	May/20	30/Mar/20
61	06161051	Braefoot Elementary	1970	May/19	1	Sink	Medical-1005	0.116	Yes	School is under seismic upgrade and d	Information is provided to School staff	None.	Aug/20	30/Mar/20
61	06161051	Braefoot Elementary	1970	May/19	1	Water Filling Station	Corridor-2005	0.005	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	May/20	30/Mar/20
61	06161047	Campus View Elementary	1964	Aug/19	1	Water Fountain	Corridor-1050	0.003	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Aug/20	30-Mar-20
61	06161047	Campus View Elementary	2001	Sep/17	2	Water Fountain	Corridor-1001	0.001	No	30 Sec flush before use until filter can	Information is provided to School staff	None.	Aug/20	30-Mar-20
61	06161047	Campus View Elementary	2001	Aug-19	1	Sink	Staff-1032	0.001	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Aug/20	30-Mar-20
61	06161047	Campus View Elementary	1964	Aug-19	1	Water Filling Station	Corridor-1009	0.001	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Aug/20	30-Mar-20
61	06161047	Campus View Elementary		Sep/17	2	Sink	Portable-0031	0.003	No	30 Sec flush before use until filter can	Information is provided to School staff	None.	Aug/20	30/Mar/20
61	06161047	Campus View Elementary		Aug/19	1	Water Fountain	Portable-0025	0.002	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Aug/20	30/Mar/20
61	06161047	Campus View Elementary		Aug/19	1	Sink	Portable-0025	0.002	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Aug/20	30/Mar/20
61	06161047	Campus View Elementary		Aug/19	1	Sink	Portable-0068	0.002	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Aug/20	30/Mar/20
61	06161047	Campus View Elementary		Aug/19	1	Water Fountain	Portable-0068	0.002	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Aug/20	30/Mar/20
61	06161047	Campus View Elementary		Sep/17	2	Sink	Portable-0117	0.002	No	30 Sec flush before use until filter can	Information is provided to School staff	None.	Aug/20	30/Mar/20
61	06161025	Cedar Hill Middle	1972	Jan/20	1	Water Fountain	Corridor-1088	0.001	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Jan/21	30-Mar-20
61	06161025	Cedar Hill Middle	1931	Jan/20	1	Sink	Staff-1078	0.001	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Jan/21	30/Mar/20
61	06161025	Cedar Hill Middle	1953	Jan/20	1	Water Filling Station	Corridor-1016	0.005	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Jan/21	30/Mar/20
61	06161025	Cedar Hill Middle	1959	Sep/17	2	Sink	Kitchen-1020	0.005	No	30 Sec flush before use until filter can	Information is provided to School staff	None.	Aug/20	30/Mar/20
61	06161025	Cedar Hill Middle	1959	Jan/20	1	Water Filling Station	Corridor-1063	0.003	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Jan/21	30/Mar/20
61	06161025	Cedar Hill Middle	1966	Jan/20	1	Water Fountain	Corridor-1051	0.004	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Jan/21	30/Mar/20
61	06161025	Cedar Hill Middle	1975	Jan/20	1	Sink	Foods-1056	0.001	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Jan/21	30/Mar/20
61	06161025	Cedar Hill Middle	1975	Jan/20	1	Sink	Foods-1056	0.004	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Jan/21	30/Mar/20
61	06161025	Cedar Hill Middle	1975	Jan/20	1	Sink	Foods-1056	0.003	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Jan/21	30/Mar/20
61	06161025	Cedar Hill Middle	1975	Jan/20	1	Sink	Foods-1056	0.002	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Jan/21	30/Mar/20
61	06161025	Cedar Hill Middle	1975	Jan/20	1	Sink	Foods-1056	0.002	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Jan/21	30/Mar/20
61	06161025	Cedar Hill Middle	1975	Jan/20	1	Sink	Foods-1056	0.002	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Jan/21	30/Mar/20
61	06161025	Cedar Hill Middle	1972	Jan/20	1	Water Filling Station	Corridor-2031	0.002	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Jan/21	30/Mar/20
61	06161025	Cedar Hill Middle	1931	Jan/20	1	Water Filling Station	Corridor-2025	0.003	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Jan/21	30/Mar/20
61	06161025	Cedar Hill Middle	1959	Jan/20	1	Water Fountain	Corridor-2003	0.004	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Jan/21	30/Mar/20
61	06161025	Cedar Hill Middle	1975	Jan/20	1	Sink	Foods-1056	0.002	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Jan/21	30/Mar/20
61	06161025	Cedar Hill Middle	1975	Sep/17	2	Sink	Foods-1056	0.005	No	30 Sec flush before use until filter can	Information is provided to School staff	None.	Aug/20	30/Mar/20
61	06161035	Central Middle School	1953	Dec-19	1	Water Filling Station	Lobby-1053	0.003	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Dec/20	30-Mar-20
61	06161035	Central Middle School	1953	Dec/19	1	Water Fountain	Cafeteria-1030	0.000	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Dec/20	30/Mar/20
61	06161035	Central Middle School	1953	Dec/19	1	Water Fountain	Corridor-1023	0.001	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Dec/20	30/Mar/20
61	06161035	Central Middle School	1953	Dec/19	1	Water Fountain	Corridor-2020	0.001	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Dec/20	30/Mar/20
61	06161035	Central Middle School	1953	Jul/16	2	Water Fountain	Corridor-2016	0.003	No	30 Sec flush before use until filter can	Information is provided to School staff	None.	Aug/20	30/Mar/20
61	06161035	Central Middle School	1953	Dec/19	1	Water Filling Station	Corridor-3019	0.003	No	Lead filter installed with lead free fixtu	Information is provided to School staff	None.	Dec/20	30/Mar/20
61	06161035	Central Middle School	1953	Jul/16	2	Sink	Servery-1031	0.002	No	30 Sec flush before use until filter can	Information is provided to School staff	None.	Aug/20	30/Mar/20

SCHOOL FACILITY INFORMATION				TEST INFORMATION						MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN			ADDITIONAL INFORMATION	
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period
61	06161040	Ecole Macaulay Elementary	1967	Oct/19	1	Sink	Class-2018	0.002	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Oct/20	30/Mar/20
61	06161046	Ecole Marigold School	1958	Jul/16	2	Water Fountain	Corridor-1046	0.003	No	30 Sec flush before use until filter can Information is provided to School staff None.			Jul/17	30-Mar-20
61	06161046	Ecole Marigold School	1958	Sep/17	2	Water Filling Station	Corridor-1046	0.001	No	30 Sec flush before use until filter can Information is provided to School staff None.			Jul/20	30/Mar/20
61	06161046	Ecole Marigold School	1962	Sep/17	2	Sink	Staff-1030	0.003	No	30 Sec flush before use until filter can Information is provided to School staff None.			Jul/20	30/Mar/20
61	06161046	Ecole Marigold School	1962	Jul/19	1	Water Filling Station	Corridor-1014	0.000	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Jul/20	30/Mar/20
61	06161046	Ecole Marigold School	1992	Aug/19	2	Water Filling Station	Corridor-1119	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Aug/20	30/Mar/20
61	06161046	Ecole Marigold School	1958	Jul/16	2	Sink	Medical-1004	0.003	No	30 Sec flush before use until filter can Information is provided to School staff None.			Jul/20	30/Mar/20
61	06161016	Ecole Quadra Elementary	1914	Sep/17	2	Water Filling Station	Corridor-0023	0.002	No	30 Sec flush before use until filter can Information is provided to School staff None.			Jul/20	30-Mar-20
61	06161016	Ecole Quadra Elementary	1992	Aug/19	2	Sink	Kitchen-0002	0.003	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Aug/20	30/Mar/20
61	06161016	Ecole Quadra Elementary	1968	Jul/19	1	Water Fountain	Corridor-1009	0.000	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Jul/20	30/Mar/20
61	06161016	Ecole Quadra Elementary	1962	Jul/19	1	Sink	Kitchen-1015	0.003	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Jul/20	30/Mar/20
61	06161016	Ecole Quadra Elementary	1913	Aug/19	2	Water Fountain	Corridor-1002	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Aug/20	30/Mar/20
61	06161016	Ecole Quadra Elementary	1914	Jul/19	1	Water Fountain	Corridor-0008	0.004	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Jul/20	30/Mar/20
61	06161016	Ecole Quadra Elementary	1992	Jul/19	1	Sink	Kitchen-0002	0.096	Yes	Sink has been shut off and labeled do Information is provided to School staff None.			Jul/20	30-Mar-20
61	06161021	Ecole Willows Elementary	1919	Dec/19	1	Water Fountain	Corridor - 0026	0.004	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161021	Ecole Willows Elementary	1919	Dec/19	1	Water Fountain	Corridor - 0026	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161021	Ecole Willows Elementary	1956	Dec/19	1	Water Fountain	Corridor - 1041	0.002	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161021	Ecole Willows Elementary	1956	Dec/19	1	Water Fountain	Corridor - 2028	0.003	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Aug/20	30/Mar/20
61	06161021	Ecole Willows Elementary	1919	Dec/19	1	Water Fountain	Corridor - 2016	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161021	Ecole Willows Elementary	1967	Dec/19	1	Sink	Staff-1001	0.002	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161021	Ecole Willows Elementary	1919	Dec/19	1	Sink	Multi-1022	0.002	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161021	Ecole Willows Elementary	1919	Dec/19	1	Sink	Medical-1006	0.003	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161021	Ecole Willows Elementary	1919	Aug/19	2	Sink	Servery-1021A	0.003	No	30 Sec flush before use until filter can Information is provided to School staff None.			Aug/20	30/Mar/20
61	06161048	Esquimalt High	1995	Dec-19	1	Water Fountain	Change-1058	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30-Mar-20
61	06161048	Esquimalt High	1995	Dec-19	1	Water Fountain	Change-1056	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161048	Esquimalt High	1959	Dec-19	1	Water Filling Station	Corridor-1036	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161048	Esquimalt High	1987	Dec/19	1	Sink	Servery-1084	0.003	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161048	Esquimalt High	1987	Dec/19	1	Sink	Kitchen-1094	0.004	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161048	Esquimalt High	1959	Dec/19	1	Sink	Lunch-1098	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161048	Esquimalt High	1959	Dec/19	1	Sink	Staff-1118	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161048	Esquimalt High	1959	Aug/19	2	Sink	Medical-1114	0.003	No	30 Sec flush before use until filter can Information is provided to School staff None.			Aug/20	30/Mar/20
61	06161048	Esquimalt High	1959	Dec/19	1	Water Filling Station	Corridor-2011	0.003	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161048	Esquimalt High	1966	Oct/19	2	Sink	Foods-2042	0.003	No	30 Sec flush before use until filter can Information is provided to School staff None.			Aug/20	30/Mar/20
61	06161048	Esquimalt High	1966	Oct/19	1	Sink	Foods-2042	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Nov/20	30/Mar/20
61	06161048	Esquimalt High	1966	Oct/19	1	Sink	Foods-2042	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Nov/20	30/Mar/20
61	06161048	Esquimalt High	1966	Oct/19	1	Sink	Foods-2042	0.002	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Nov/20	30/Mar/20
61	06161048	Esquimalt High	1966	Oct/19	1	Sink	Foods-2042	0.002	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Nov/20	30/Mar/20
61	06161048	Esquimalt High	1959	Dec/19	1	Water Fountain	Corridor-3009	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161048	Esquimalt High	1959	Dec/19	1	Water Fountain	Corridor-3009	0.000	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161048	Esquimalt High	1967	Dec/19	1	Water Filling Station	Corridor-3028	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161048	Esquimalt High	1967	Oct/19	1	Sink	Foods-3031	0.003	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Nov/20	30/Mar/20
61	06161048	Esquimalt High	1967	Oct/19	1	Sink	Foods-3031	0.003	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Nov/20	30/Mar/20
61	06161048	Esquimalt High	1967	Oct/19	1	Sink	Foods-3031	0.003	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Nov/20	30/Mar/20
61	06161048	Esquimalt High	1967	Oct/19	1	Sink	Foods-3031	0.002	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Nov/20	30/Mar/20
61	06161048	Esquimalt High	1967	Oct/19	1	Sink	Foods-3031	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Nov/20	30/Mar/20
61	06161048	Esquimalt High	1967	Oct/19	1	Sink	Foods-3031	0.002	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Nov/20	30/Mar/20
61	06161048	Esquimalt High	1967	Oct/19	1	Sink	Foods-3031	0.004	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Nov/20	30/Mar/20
61	06161048	Esquimalt High	1966	Dec/19	1	Water Fountain	Corridor-2016	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161048	Esquimalt High	1987	Dec/19	1	Sink	Kitchen-1094	0.004	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161048	Esquimalt High	1987	Dec/19	1	Other	Kitchen-1094	0.003	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161048	Esquimalt High	1959	Dec/19	1	Sink	Class-1100	0.008	Yes	Sink has been shut off and labeled do Information is provided to School staff None.			Aug/20	30/Mar/20
61	06161048	Esquimalt High	1987	Dec/19	1	Sink	Kitchen-1094	0.009	Yes	Sink has been shut off and labeled do Information is provided to School staff None.			Aug/20	30/Mar/20
61	06161030	Frank Hobbs Elementary	1950	Aug/19	1	Water Fountain	Corridor-1056	0.000	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Aug/20	30-Mar-20
61	06161030	Frank Hobbs Elementary	1961	Apr/19	2	Water Filling Station	Corridor-1075	0.004	No	30 Sec flush before use until filter can Information is provided to School staff None.			Aug/20	30/Mar/20
61	06161030	Frank Hobbs Elementary	1961	Oct/18	2	Sink	Staff-1072	0.001	No	30 Sec flush before use until filter can Information is provided to School staff None.			Aug/20	30/Mar/20
61	06161030	Frank Hobbs Elementary	1957	Apr/19	2	Water Filling Station	Corridor-1056	0.002	No	30 Sec flush before use until filter can Information is provided to School staff None.			Aug/20	30/Mar/20
61	06161030	Frank Hobbs Elementary	1972	Oct/18	2	Sink	Class-0004	0.002	No	30 Sec flush before use until filter can Information is provided to School staff None.			Aug/20	30/Mar/20
61	06161030	Frank Hobbs Elementary	1964	Apr/19	1	Water Filling Station	Corridor-1075	0.000	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Apr/20	30/Mar/20
61	06161030	Frank Hobbs Elementary	1964	Apr/19	1	Sink	Class-1064	0.044	Yes	Sink has been shut off and labeled do Information is provided to School staff None.			Apr/20	30/Mar/20
61	06161005	George Jay Elementary	1972	Oct/18	2	Water Filling Station	Corridor-1000	0.000	No	30 Sec flush before use until filter can Information is provided to School staff None.			Aug/20	30-Mar-20
61	06161005	George Jay Elementary	1909	Oct/18	2	Water Filling Station	Corridor-1011	0.000	No	30 Sec flush before use until filter can Information is provided to School staff None.			Aug/20	30/Mar/20
61	06161005	George Jay Elementary	1909	Oct/18	2	Water Filling Station	Corridor-1011	0.000	No	30 Sec flush before use until filter can Information is provided to School staff None.			Aug/20	30/Mar/20
61	06161005	George Jay Elementary	1956	Oct/18	2	Water Filling Station	Corridor-1038	0.000	No	30 Sec flush before use until filter can Information is provided to School staff None.			Aug/20	30/Mar/20
61	06161005	George Jay Elementary	1962	Oct/18	2	Water Filling Station	Corridor-1045	0.001	No	30 Sec flush before use until filter can Information is provided to School staff None.			Aug/20	30/Mar/20
61	06161005	George Jay Elementary	1909	Oct/18	2	Water Filling Station	Corridor-2052	0.000	No	30 Sec flush before use until filter can Information is provided to School staff None.			Aug/20	30/Mar/20
61	06161005	George Jay Elementary	1962	Oct/18	2	Water Filling Station	Corridor-2038	0.000	No	30 Sec flush before use until filter can Information is provided to School staff None.			Aug/20	30/Mar/20
61	06161005	George Jay Elementary	1956	Oct/18	2	Water Filling Station	Corridor-2039	0.001	No	30 Sec flush before use until filter can Information is provided to School staff None.			Aug/20	30/Mar/20
61	06161005	George Jay Elementary	1909	Aug/19	1	Sink	Staff-2014	0.002	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Aug/20	30/Mar/20
61	06161005	George Jay Elementary	1909	Oct/18	2	Sink	Class-1020	0.001	No	30 Sec flush before use until filter can Information is provided to School staff None.			Aug/20	30/Mar/20
61	06161005	George Jay Elementary	1972	Oct/18	2	Sink	Kitchen-1003	0.001	No	30 Sec flush before use until filter can Information is provided to School staff None.			Aug/20	30/Mar/20
61	06161038	Glanford Middle School	1955	Feb/20	1	Water Fountain	Corridor-1074	0.003	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Feb/21	30-Mar-20
61	06161038	Glanford Middle School	2004	Feb/20	1	Water Fountain	Corridor-1055	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Feb/21	30/Mar/20

SCHOOL FACILITY INFORMATION				TEST INFORMATION						MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN			ADDITIONAL INFORMATION	
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period
61	06161018	Victoria High	2011	Dec/19	1	Water Fountain	Concourse-1050	0.002	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161018	Victoria High	2011	Dec/19	1	Water Filling Station	Concourse-1050	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161018	Victoria High	1911	Dec/19	1	Water Filling Station	Corridor-2055	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161018	Victoria High	1911	Dec/19	1	Water Filling Station	Corridor-3012	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161018	Victoria High	1911	Dec/19	1	Water Filling Station	Corridor-4032	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161018	Victoria High	1911	Dec/19	1	Sink	Kitchen-1002	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161018	Victoria High	1911	Oct/19	1	Sink	Foods-1013	0.002	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Oct/20	30/Mar/20
61	06161018	Victoria High	1911	Oct/19	1	Sink	Foods-1013	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Oct/20	30/Mar/20
61	06161018	Victoria High	1911	Oct/19	1	Sink	Foods-1013	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Oct/20	30/Mar/20
61	06161018	Victoria High	1911	Oct/19	1	Sink	Foods-1013	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Oct/20	30/Mar/20
61	06161018	Victoria High	1911	Oct/19	1	Sink	Foods-1013	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Oct/20	30/Mar/20
61	06161018	Victoria High	1911	Oct/19	1	Sink	Foods-1013	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Oct/20	30/Mar/20
61	06161018	Victoria High	1911	Oct/19	1	Sink	Foods-1013	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Oct/20	30/Mar/20
61	06161018	Victoria High	1911	Oct/19	1	Sink	Foods-1013	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Oct/20	30/Mar/20
61	06161018	Victoria High	1911	Dec/19	1	Sink	Kitchen-2020	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161018	Victoria High	1911	Dec/19	1	Water Fountain	Gym-0030	0.000	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161004	Victoria West Elementary	1971	Dec/19	1	Water Filling Station	Corridor-1064	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30-Mar-20
61	06161004	Victoria West Elementary	1971	Dec/19	1	Water Fountain	Corridor-1064	0.003	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161004	Victoria West Elementary	1971	Jan/17	2	Sink	Medical-1057	0.002	No	30 Sec flush before use until filter can Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161004	Victoria West Elementary	1971	Dec/19	1	Sink	Staff-1055	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161004	Victoria West Elementary	1969	Dec/19	1	Water Fountain	Corridor-1049	0.003	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161004	Victoria West Elementary	1969	Dec/19	1	Water Filling Station	Corridor-1049	0.000	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161004	Victoria West Elementary	1971	Dec/19	1	Water Fountain	Corridor-1032	0.000	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161004	Victoria West Elementary	1910	Dec/19	1	Sink	Annex-A1001	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161004	Victoria West Elementary	1969	Dec/19	1	Sink	Kitchen-1038	0.023	Yes	Sink has been shut off and labeled do Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161004	Victoria West Elementary	1969	Dec/19	1	Sink	Kitchen-1038	0.002	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161004	Victoria West Elementary	1969	Dec/19	1	Sink	Kitchen-1038	0.006	Yes	Sink has been shut off and labeled do Information is provided to School staff None.			Dec/20	30/Mar/20
61	06161029	View Royal Elementary	2000	Jul/19	1	Sink	Kitchen-Daycare	0.002	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Aug/20	30-Mar-20
61	06161029	View Royal Elementary	2000	Jul/19	1	Sink	Activity-Daycare	0.003	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Aug/20	30-Mar-20
61	06161029	View Royal Elementary	1948	Oct/19	1	Water Filling Station	Corridor-1065	0.000	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Oct/20	30-Mar-20
61	06161029	View Royal Elementary	1963	Oct/19	1	Sink	Medical-1007A	0.003	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Oct/20	30-Mar-20
61	06161029	View Royal Elementary	1965	Oct/19	1	Sink	Staff-1042	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Oct/20	30-Mar-20
61	06161029	View Royal Elementary	1948	Oct/19	1	Water Filling Station	Corridor-1019	0.000	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Oct/20	30-Mar-20
61	06161029	View Royal Elementary	1986	Oct/19	1	Sink	Class-0027	0.004	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Oct/20	30-Mar-20
61	06161029	View Royal Elementary	2000	Oct/19	1	Water Fountain	Washroom-Daycare	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Oct/20	30-Mar-20
61	06161029	View Royal Elementary	1953	Oct/19	1	Water Fountain	Corridor-1031	0.002	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Oct/20	30-Mar-20
61	06161029	View Royal Elementary	1965	Oct/19	1	Sink	Kitchen-1044	0.002	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Oct/20	30-Mar-20
61	06161029	View Royal Elementary	2000	Oct/19	1	Sink	Activity-Daycare	0.001	No	Lead filter installed with lead free fixtu Information is provided to School staff None.			Oct/20	30-Mar-20