

Ministry of Education - Capital Management Branch

2020/21 REPORT FOR TESTING LEAD CONTENT IN DRINKING WATER OF SCHOOL FACILITIES

Scho	ol District Information	Health Authority (HA) Information						
SD No.	61	Region	Victoria Island Health Authority					
SD Name	Greater Victoria	Contact Name	Stacey Sowa					
SD Contact Name:	Justin Taylor	Contact Phone	stacey.sowa@vha.ca					
SD Contact Phone:		Report Submitted to HA	Yes					
Report Date	2021-03-25	Report Submission Date	2021-03-25					

Click here to access the School Master List for Facility Names and Facility Codes.

	SCHOOL FACILITY INFORMATION					TEST	INFORMATION	-		MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN		ADDITIONAL INFORMATION		
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	xceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period
61	06161062	Arbutus Global Middle School Arbutus Global Middle School	1969	Aug-20 Nov-19	1	Water Fountain	Corridor-1079 Staff-1004	0.001	No	Lead filter installed with lead free fixtue	€Information is provided to School staff w €Information is provided to School staff w	None.	Jul-21 Jul-21	19-Mac-21 30-Mac-21 30-Mac-21 30-Mac-21 30-Mac-21 30-Mac-21 30-Mac-21 30-Mac-21 30-Mac-21 30-Mac-21 30-Mac-21 30-Mac-21
61	06161062	Arbutus Global Middle School	1969	Aug-19	1	Water Fountain	Corridor-1040	0.004	No	Lead filter installed with lead free fixtu	e Information is provided to School staff w	None.	Jul-21	30-Mar-21
61 61	06161062 06161062	Arbutus Global Middle School Arbutus Global Middle School	1969 1969	Aug-20 Aug-20	1	Sink Sink	Foods-1035 Foods-1035	0.003 0.002	No No	Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur	Enformation is provided to School staff w Enformation is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21
61 61	06161062	Arbutus Global Middle School Arbutus Global Middle School	1969 1969	Aug-20 Oct-19	2	Sink Sink	Foods-1035 Foods-1035	0.001	No No	30 Sec flush before use until filter can b Lead filter installed with lead free fixture	e Information is provided to School staff w ∈ Information is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21
61	06161062	Arbutus Global Middle School	1969	Aug-20	1	Sink	Foods-1035	0.001	No	Lead filter installed with lead free fixture	Information is provided to School staff w	None.	Jul-21	30-Mar-21
61 61	06161062 06161062	Arbutus Global Middle School Arbutus Global Middle School	1969	Aug-20 Aug-20	2 1	Sink Water Filling Station	Foods-1035 Corridor-1044	0.001	No	Lead filter installed with lead free fixtur	e Information is provided to School staff w e Information is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21
61 61	06161062 06161062	Arbutus Global Middle School Arbutus Global Middle School	1969 1969	Nov-19 Nov-19	1	Water Fountain Water Fountain	Changeroom - 0002 Changeroom - 0008	0.003	No No	Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur	EInformation is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21
61	06161062	Arbutus Global Middle School	1969	Aug-20	1	Sink	Foods-1035	0.004	No	Lead filter installed with lead free fixtu	e Information is provided to School staff w		Jul-21	30-Mar-21 30-Mar-21 30-Mar-21
61 61	06161062 06161062	Arbutus Global Middle School Arbutus Global Middle School	1969 1975	Aug-20 Apr-20 Oct-19	2	Sink Sink	Foods-1035 Kitchen-1060	0.000	NO NO	30 Sec flush before use until filter can b	e Information is provided to School staff w e Information is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21
61 61	06161062 06161051	Arbutus Global Middle School Braefoot Elementary	1969	Oct-19 Sep-20	2	Sink	Foods-1035 Kitchen-1037	0.003	No No		e Information is provided to School staff w e Information is provided to School staff w		Jul-21 Jul-21	30-Mar-21 30-Mar-21
61	06161051	Braefoot Elementary	1971	May-19	1	Sink Water Fountain	Corridor-1043	0.004	No	Lead filter installed with lead free fixtu	e Information is provided to School staff w	None.	Jul-21	30-Mar-21 30-Mar-21
61 61	06161051 06161051	Braefoot Elementary Braefoot Elementary	1971 1970	Sep-20 Sep-20	1	Water Filling Station Sink	Corridor - 1043 Staff-1024	0.001	NO NO	Lead filter installed with lead free fixtur	Enformation is provided to School staff w Enformation is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21
61 61	06161051 06161051	Braefoot Elementary Braefoot Elementary	1970 1970	May-19 May-19	1	Water Filling Station Water Filling Station	Corridor-1049 Corridor-2005	0.000	No No		Enformation is provided to School staff w Enformation is provided to School staff w		Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21
61	06161051	Braefoot Elementary	1970	May-19	1	Sink	Class-2006	0.004	No	Lead filter installed with lead free fixture	EInformation is provided to School staff w	None.	Jul-21	30-Mar-21 30-Mar-21
61 61	06161051 06161051	Braefoot Elementary Braefoot Elementary	1970 1970	Sep-20 May-19	1	Sink Water Filling Station	Medical-1005 Corridor-2005	0.002	No		e Information is provided to School staff w e Information is provided to School staff w		Jul-21 Jul-21	30-Mar-21 30-Mar-21
61 61	06161047 06161047	Campus View Elementary Campus View Elementary	1964 2001	Aug-19 Sep-17	1	Water Fountain Water Fountain	Corridor-1050 Corridor-1001	0.000	No No		Enformation is provided to School staff w e Information is provided to School staff w		Jul-21 Jul-21	30-Mar-21 30-Mar-21
61	06161047	Campus View Elementary	2001	Aug-19	2	Sink	Staff-1002 Corridor-1009	0.001	No	30 Sec flush before use until filter can b	e Information is provided to School staff w	None.	Jul-21	30-Mar-21 30-Mar-21 30-Mar-21
61 61	06161047 06161047	Campus View Elementary Campus View Elementary	1964	Aug-19 Sep-17	1 2	Water Filling Station Sink	Corridor-1009 Portable-0031	0.001	No	30 Sec flush before use until filter can b	e Information is provided to School staff w e Information is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21
61 61	06161047 06161047	Campus View Elementary Campus View Elementary		Sep-17 Sep-17	2	Water Fountain Sink	Portable-0025 Portable-0025	0.001	No	30 Sec flush before use until filter can b	e Information is provided to School staff w e Information is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21
61	06161047	Campus View Elementary		Sep-17	2	Sink	Portable-0068	0.002	No	30 Sec flush before use until filter can b	e Information is provided to School staff w	None.	Jul-21	30-Mar-21 30-Mar-21
61 61	06161047 06161047	Campus View Elementary Campus View Elementary		Sep-17 Dec-20	2	Water Fountain Sink	Portable-0068 Portable-0117	0.001	No No	30 Sec flush before use until filter can b Lead filter installed with lead free fixture	e Information is provided to School staff w € Information is provided to School staff w	None. None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21
61	06161025	Cedar Hill Middle Cedar Hill Middle	1972	Jan-20	1	Water Fountain Sink	Corridor-1088	0.001	No	Lead filter installed with lead free fixture	eInformation is provided to School staff w eInformation is provided to School staff w	None.	Jul-21	30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21
61	06161025	Cedar Hill Middle	1953	Jan-20 Jan-20	1	Water Filling Station	Corridor-1088 Staff-1078 Corridor-1016	0.001	No	Lead filter installed with lead free fixture	e Information is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21
61 61	06161025 06161025	Cedar Hill Middle Cedar Hill Middle	1959 1959	Sep-20 Jan-20	1	Sink Water Filling Station	Kitchen-1020 Corridor-1063	0.003	No No	Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur	Enformation is provided to School staff w Enformation is provided to School staff w	None. None.	Jul-21 Jul-21	
61	06161025 06161025	Cedar Hill Middle Cedar Hill Middle	1966	Jan-20	1	Water Fountain	Corridor-1051	0.003	No	Lead filter installed with lead free fixtue	e Information is provided to School staff w e Information is provided to School staff w suffermation is provided to School staff w	None.	Jul-21	30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21
61	06161025	Cedar Hill Middle	1975	Jan-20 Jan-20	1	Sink Sink	Foods-1056 Foods-1056	0.001	No	Lead filter installed with lead free fixture	Enformation is provided to School staff w Enformation is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21
61 61	06161025 06161025	Cedar Hill Middle Cedar Hill Middle	1975	Jan-20 Jan-20	····· 1	Sink	Foods-1056 Foods-1056	0.003	No No	Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur	Enformation is provided to School staff w Enformation is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21
61	06161025 06161025	Cedar Hill Middle Cedar Hill Middle	1975	Jan-20 Jan-20	1	Sink Sink	Foods-1056 Foods-1056	0.002	No	Lead filter installed with lead free fixtu	€ Information is provided to School staff w € Information is provided to School staff w	None.	Jul-21	30-Mar-21
61	06161025	Cedar Hill Middle	1975	Jan-20	1	Water Filling Station	Corridor-2031	0.002	NO	Lead filter installed with lead free fixtu	e Information is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21
61 61	06161025 06161025	Cedar Hill Middle Cedar Hill Middle	1931 1959	Jan-20 Jan-20		Water Filling Station Water Fountain	Corridor-2025 Corridor-2003	0.003 0.004	No	Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur	Enformation is provided to School staff w Enformation is provided to School staff w	None. None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21
61	06161025 06161025	Cedar Hill Middle Cedar Hill Middle	1975	Jan-20	1	Sink Sink	Foods-1056 Foods-1056	0.002	No	Lead filter installed with lead free fixtu	Enformation is provided to School staff w Enformation is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21
61	06161025	Cedar Hill Middle	1973	Sep-20	2	Sink	Medical-1069	0.001	No	30 Sec flush before use until filter can b	e Information is provided to School staff w	None.	Jul-21	30-Mar-21 30-Mar-21
61 61	06161025 06161035	Cedar Hill Middle Central Middle School	1931 1953	Sep-20 Dec-19	1	Sink Water Filling Station	Room-2009 Lobby-1053	0.000	No No	Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur	∈Information is provided to School staff w ∈Information is provided to School staff w	None. None.	Jul-21 Jul-21	30-Mar-21
61	06161035 06161035	Central Middle School Central Middle School		Dec-19	1	Water Fountain Water Fountain	Cafeteria-1030 Corridor-1023	0.000	No	Lead filter installed with lead free fixtu	Enformation is provided to School staff w Enformation is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21
61	06161035	Central Middle School		Dec-19 Dec-19	1	Water Fountain	Corridor-2020	0.001	No	Lead filter installed with lead free fixtu	Information is provided to School staff w	None.	Jul-21	30-Mar-21
61 61	06161035 06161035	Central Middle School Central Middle School	1953 1953	Nov-20 Dec-19	1	Water Fountain Water Filling Station	Corridor-2016 Corridor-3019	0.002	No No	Lead filter installed with lead free fixture	e Information is provided to School staff w e Information is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21
61	06161035 06161035	Central Middle School Central Middle School	1953	Jul-16 Aug-19	2	Sink	Servery-1031 Foods-2026	0.004	No	30 Sec flush before use until filter can b	e Information is provided to School staff w e Information is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21
61	06161035	Central Middle School	1953	Oct-19	1	Sink	Foods-2026	0.001	No	Lead filter installed with lead free fixtur	e Information is provided to School staff w	None.	Jul-21	30-Mar-21
61 61	06161035 06161035	Central Middle School Central Middle School	1953	Oct-19 Oct-19	1 1	Sink Sink	Foods-2026 Foods-2026	0.001	No	Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur	e Information is provided to School staff w e Information is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21
61 61	06161035	Central Middle School Central Middle School	1953	Oct-19 Oct-19	1	Sink	Foods-2026 Foods-2026	0.002	No	Lead filter installed with lead free fixture	€ Information is provided to School staff w € Information is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21
61	06161035	Central Middle School	1953	Oct-19	1	Sink	Foods-2026	0.001	No	Lead filter installed with lead free fixtu	e Information is provided to School staff w	None.	Jul-21	30-Mar-21
61 61	06161035 06161035	Central Middle School Central Middle School	1953	Oct-19 Dec-20	1 1	Sink Water Fountain	Foods-2026 Metal-2010	0.002	No	Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur	€ Information is provided to School staff w € Information is provided to School staff w	None. None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21
61 61	06161019	Cloverdale Traditional Elementary Cloverdale Traditional Elementary	1982	Aug-19	1	Sink Water Fountain	Class-1030 Corridor-1002	0.001	No	Lead filter installed with lead free fixture	€ Information is provided to School staff w € Information is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21
61	06161019	Cloverdale Traditional Elementary	1967	Jan-20 Jan-20	1	Water Fountain	Corridor-1002	0.002	No	Lead filter installed with lead free fixtur	e Information is provided to School staff w	None.	Jul-21	30 Mar. 21 30 Mar. 21
61	06161019	Cloverdale Traditional Elementary Cloverdale Traditional Elementary	1967 1964	Jan-20 Jan-20	1	Water Filling Station Sink	Corridor-2040 Staff-2043	0.001 0.003	No No	Lead filter installed with lead free fixtu	∈Information is provided to School staff w ∈Information is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21
61	06161019 06161019	Cloverdale Traditional Elementary Cloverdale Traditional Elementary	1964 1963	Jan-20 Jan-20	1	Sink Water Filling Station Water Filling Station	Corridor-2049 Corridor-2017	0.001	No		EInformation is provided to School staff w EInformation is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21
61	06161019	Cloverdale Traditional Elementary		Jan-20	1	Sink	Portable-0085	0.004	No	Lead filter installed with lead free fixtu	e Information is provided to School staff w	None.	Jul-21	3U-IVI81-21
61	06161019 06161019	Cloverdale Traditional Elementary Cloverdale Traditional Elementary	1967 1964	Oct-20 Jan-20	1	Water Fountain Sink Water Fountain	Corridor-1010 Medical-2045	0.001	NO No	Lead filter installed with lead free fixtu	Enformation is provided to School staff w Enformation is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21
61	06161068 06161068	Colquitz Middle School Colquitz Middle School		Aug-19 Jan-19	1	Water Fountain Water Filling Station	Corridor-1078 Corridor-1050	0.001	No		EInformation is provided to School staff w EInformation is provided to School staff w		Jul-21 Jul-21	30-Mar-21 30-Mar-21
61	06161068	Colquitz Middle School	2004	Jan-19	1	Water Filling Station	Corridor-1003	0.001	No	Lead filter installed with lead free fixture	EInformation is provided to School staff w	None.	Jul-21	30-Mar-21 30-Mar-21
61	06161068 06161068	Colquitz Middle School Colquitz Middle School	2004 2004	Jan-19 Aug-19	1	Sink Sink	Staff-1013 Foods-1086	0.001 0.003	No No		Enformation is provided to School staff w Enformation is provided to School staff w		Jul-21 Jul-21	30-Mar-21 30-Mar-21
	06161068 06161068	Colquitz Middle School	2004 2004	Aug-19 Aug-19	2	Sink	Foods-1086	0.002 0.003	No No	Lead filter installed with lead free fixture	Information is provided to School staff w	None.	Jul-21	30-Mar-21
61	06161068	Colquitz Middle School Colquitz Middle School	2004	Aug-19	1	Sink	Foods-1086 Foods-1086	0.005	No	Lead filter installed with lead free fixtu	EInformation is provided to School staff w EInformation is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21
61 61	06161068 06161068	Colquitz Middle School Colquitz Middle School	2004 2004	Aug-19 Aug-19	1	Sink Sink	Foods-1086 Foods-1086	0.005 0.002	No No	Lead filter installed with lead free fixtu	Enformation is provided to School staff w Enformation is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21
61	06161068		2004	Jan-19	1	Sink	Foods-1086	0.001	No		e Information is provided to School staff w		Jul-21	30-Mar-21

	SCHOOL FACILITY INFO	RMATION	-			TEST I	NFORMATION			MITIGATION STRATEGY & PUBLIC	COMMUNICATION PLAN		ADDITIONAL INFORMATION	
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period
61 61	06161068 06161068	Colquitz Middle School Colquitz Middle School Craigflower Elementary	2004 2004	Jan-19 Jan-19 Jan-19	1 1	Sink Sink	Medical-1098 Servery-1076	0.004 0.002	No No	Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur	Information is provided to School staff w Information is provided to School staff w	None. None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21
61 61 61	06161010 06161010 06161010		1963	Jan-19	1	Water Fountain Sink Sink	Corridor-1044 Staff-0001 Medical-1003	0.001 0.001 0.004			Information is provided to School staff w Information is provided to School staff w Information is provided to School staff w	None. None. None.	Jul-21 Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21
61 61 51	06161010 06161010 06151010	Craigflower Elementary Craigflower Elementary Craigflower Elementary Craigflower Elementary Craigflower Elementary Craigflower Elementary	1963 1963 1963	Jan-19 Jan-19	1	Sink Water Filling Station Sink Sink	Corridor-1044 Kitchen-1028 Kitchen-1028	0.002 0.002 0.003	No No No	Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur	Information is provided to School staff w Information is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21
61 61	06161010 06161010	Craigflower Elementary Craigflower Elementary Doncaster Elementary	1963 1963	Jan-19 Jan-19	1	Sink Water Filling Station	Kitchen-1028 Corridor-2025	0.002	No No	Lead filter installed with lead free fixtun Lead filter installed with lead free fixtun	Information is provided to School staff w Information is provided to School staff w	None. None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21
61 61 61	06161028 06161028 06161028	Doncaster Elementary Doncaster Elementary Doncaster Elementary Doncaster Elementary	2010 2010 1963	Jan-20 Jan-20 Jan-20	1 1 1	Water Filling Station Water Fountain Water Fountain	Corridor-2025 Corridor-1012 Corridor-1012 Corridor-1014 Corridor-1035	0.001 0.001 0.001	No No No	Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur	Information is provided to School staff w information is provided to School staff w	None. None.		30-Mar-21 30-Mar-21 30-Mar-21 20 Mar-21
61 61 61	06161028 06161028 06161028	Doncaster Elementary Doncaster Elementary Doncaster Elementary	1964 1945 2010	Jan-20 Jan-20 Jan-20	1	Water Fountain Water Filling Station Water Fountain	Corridor-1036 Corridor-1037 Corridor-1059	0.001 0.002 0.001	No No No	Lead filter installed with lead free fixtun Lead filter stalled with lead free fixtun	Information is provided to School staff w Information is provided to School staff w Information is provided to School staff w	None. None. None.	JUI-21	30°Wia1*21
61 61	06161028 06161028	Doncaster Elementary Doncaster Elementary Eagle View Elementary	2010 1955	Jan-20 Jan-20	1	Sink Sink	Staff-1078 Class-1068	0.001	No No	Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur	Information is provided to School staff w Information is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21
61 61	06161067 06161067 06161067		1999 1999 1999	Jul-16 Jul-16 Dec-19	1 1 1	Sink Sink Sink	Class-1068 Medical-1004 Class-1006 Class-1009	0.004 0.004 0.001	NO NO NO	Lead filter installed with lead free fixture Lead filter installed with lead free fixture Lead filter installed with lead free fixture	Information is provided to School staff w Information is provided to School staff w Information is provided to School staff w Information is provided to School staff w	None. None.	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	
61 61 61	06161067 06161067 06161067	Eagle View Elementary Eagle View Elementary	1999 1999 1999	Jul-16 Jul-16 Dec-19	1 1 1	Sink Sink Sink Sink Sink Sink	Staff-1052 Class-1044 Class-1043	0.003 0.005 0.001	No No No	Lead filter installed with lead free fixture Lead filter installed with lead free fixture Lead filter installed with lead free fixture	Information growdod D Gobos (174 m) Information grow	None. None. None.	Jul-21 Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21
61 61	06161067 06161067 06151067	Eagle View Elementary Eagle View Elementary Fagle View Elementary	1999 1999 1999	Jul-16 Jul-16 Jul-16	1	Sink Sink Sink	Class-1043 Class-1042 Class-1040 Class-1039	0.002	No No No	Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur	Information is provided to School staff w Information is provided to School staff w	None.	Jul-21 Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21
61 61	06161067 06161067	Eagle View Elementary Eagle View Elementary	1999 1999	Jul-16 Jul-16 Jul-16	1	Sink Water Fountain	Class-1038 Corridor-1028	0.003	No No	Lead filter installed with lead free fixtun Lead filter installed with lead free fixtun	Information is provided to School staff w Information is provided to School staff w	None. None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21
61 61	06161067 06161067 06161067	Eagle View Elementary Eagle View Elementary Eagle View Elementary Eagle View Elementary	1999 1999 1999	Jul-16 Jul-16 Jul-16 Jul-16	1 1 1	Sink Sink Sink	Class-1030 Class-1029 Class-1027 Class-1026	0.003 0.003 0.003	No No No	Lead filter installed with lead free fixture Lead filter installed with lead free fixture Lead filter installed with lead free fixture	Information is provided to School staff w Information is provided to School staff w Information is provided to School staff w Information is provided to School staff w	None. None. None.	Jui-21 Jui-21 Jui-21	30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21
61 61 61	06161067 06161067 06161040	Eagle View Elementary Eagle View Elementary Ecole Macaulay Elementary Ecole Macaulay Elementary	1999 1999 1954	Jul-16 Dec-19 Jul-19	1 1 1	Sink Sink Water Fountain	Class-1026 Kitchen-1023 Corridor-1055	0.003 0.001 0.004	No No No	Lead filter installed with lead free fixtun Lead filter installed with lead free fixtun Lead filter installed with lead free fixtun Lead filter installed with lead free fixtun	Enformation is provided to School staff w Enformation is provided to School staff w Enformation is provided to School staff w Enformation is provided to School staff w	None. None. None.	Jul-21 Jul-21 Jul-21	30-Mar-21 30-Mar-21
61 61	06161040 06161040	Ecole Macaulay Elementary	1954 1967	Jul-19 Oct-19	1	Water Filling Station Water Fountain	Corridor-1055 Corridor-1045	0.002	No No	Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur	Information is provided to School staff w Information is provided to School staff w	None. None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21
61 61	06161040 06161040 06161040	Ecole Macaulay Elementary Ecole Macaulay Elementary Ecole Macaulay Elementary Ecole Macaulay Elementary	1954	Oct-19 Oct-19 Oct-19	1 1 1	Sink Sink Water Fountain Water Filling Station	Portable-OSC Corridor-2008	0.000	NO NO NO	Lead filter installed with lead free fixtun Lead filter installed with lead free fixtun Lead filter installed with lead free fixtun	Enformation is provided to School staff w Enformation is provided to School staff w Enformation is provided to School staff w Enformation is provided to School staff w	None. None. None.	Jul-21 Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21
61 61 61	06161040 06161040 06161040	Ecole Macaulay Elementary Ecole Macaulay Elementary	1962 1954 1967	Oct-19 Oct-19 Oct-19 Jul-16	1 2 1	Water Filling Station Sink Sink	Corridor-2037 Medical-1056 Class-2018	0.001 0.001 0.002	No No No	Lead filter installed with lead free fixtun 30 Sec flush before use until filter can be Lead filter installed with lead free fixtun	Information is provided to School staff w Information is provided to School staff w Information is provided to School staff w	None. None. None.	Jul-21 Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21
61 61	06161046 06161046	Ecole Marigold School Ecole Marigold School	1958 1958	Jul-16 Sep-17	2	Water Filling Station Sink Sink Water Fountain Water Filling Station Sink Water Filling Station	Corridor-1046 Corridor-1046	0.003 0.001	No No	30 Sec flush before use until filter can be 30 Sec flush before use until filter can be	Information is provided to School staff w Information is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21
61 61	06161046 06161046 06161046	Ecole Marigold School Ecole Marigold School	1962 1962 1992	Jul-19 Aug-19	2 1 2	Water Filling Station Water Filling Station Water Filling Station Sink	Combor 1014	0.000	NO NO NO	Lead filter installed with lead free fixtur 30 Sec flush before use until filter can be		None. None. None.	Jul-21 Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21
61 61 61	06161046 06161016 06161016	Ecole Marigold School Ecole Quadra Elementary Ecole Quadra Elementary Ecole Quadra Elementary	1958 1914 1992	Jul-16 Mar-21 Aug-19	2 1 2	Sink Water Filling Station Sink Water Fountain	Medical-1004 Corridor-0023 Kitchen-0002 Corridor-1009	0.003 0.000 0.003	No No No	30 Sec flush before use until filter can be Lead filter installed with lead free fixture 30 Sec flush before use until filter can be	Information is provided to School staff w Information is provided to School staff w Information is provided to School staff w Information is provided to School staff w	None. None. None.	Jul-21 Jul-21 Jul-21	30-Mar-21 30-Mar-21
61 61	06161016 06161016	Ecole Quadra Elementary Ecole Quadra Elementary Ecole Quadra Elementary	1968 1962	Aug-20 Mar-21	1	Water Fountain Sink Water Fountain	Corridor-1009 Kitchen-1015 Corridor-1002 Corridor-0008	0.001 0.000	No No	Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur 20 Sec fluch before use until filter see be	Information is provided to School staff w Information is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21
61 61	06161016 06161016 06161016	Ecole Quadra Elementary Ecole Quadra Elementary Ecole Quadra Elementary Ecole Quadra Elementary Ecole Quadra Elementary Ecole Willows Elementary Ecole Willows Elementary	1913 1914 1992	Aug-19 Jul-19 Mar-21 Dec-19	1 1	Water Fountain Water Fountain Sink Water Fountain	Corridor-0008 Kitchen-0002 Corridor - 0026	0.001 0.004 0.000	NO NO NO	Lead filter installed with lead free fixture Sink has been shut off and labeled do no	Information is provided to School tarf w information is provided in School Tarf w information is provided in School Tarf w information is provided to School Tarf w	None. None. None.	Jul-21 Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21
61 61 61	06161021 06161021 06161021	Ecole Willows Elementary Ecole Willows Elementary Ecole Willows Elementary Ecole Willows Elementary Ecole Willows Elementary	1919 1919 1956	Dec-19 Dec-19 Dec-19	1 1 1	Water Fountain Water Fountain Water Fountain Water Fountain Water Fountain	Corridor - 0026 Corridor - 0026 Corridor - 1041	0.004 0.001 0.002	No No No	Lead filter installed with lead free fixture Lead filter installed with lead free fixture Lead filter installed with lead free fixture	Information is provided to School staff w Information is provided to School staff w Information is provided to School staff w	None. None. None.	Jul-21 Jul-21 Jul-21	30-Mar-21 30-Mar-21
61 61	06161021 06161021	Ecole Willows Elementary Ecole Willows Elementary Ecole Willows Elementary	1956 1919 1967	Dec-19 Dec-19 Dec-19 Dec-19 Dec-19 Dec-19	1	Water Fountain Water Fountain	Corridor - 0026 Corridor - 0026 Corridor - 1041 Corridor - 2028 Corridor - 2016 Staff-1001 Medit-1022	0.003	No No	Lead filter installed with lead free fixture Lead filter installed with lead free fixture Lead filter installed with lead free fixture	Information is provided to School staff w Information is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21
61 61	06161021 06161021 06161021	Ecole Willows Elementary Ecole Willows Elementary Ecole Willows Elementary Ecole Willows Elementary	1907 1919 1919	Dec-19 Dec-19 Dec-19 Feb-21	1 1 1	Sink Sink Sink	Multi-1022 Medical-1006 Servery-1021A	0.002 0.002 0.003	No No	Lead filter installed with lead free fixtun Lead filter installed with lead free fixtun Lead filter installed with lead free fixtun	Information is provided to School staff w Information is provided to School staff w Information is provided to School staff w	None. None.	Jul-21	30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21
61 61 61	06161021 06161048 06161048	Ecole Willows Elementary Esquimalt High Esquimalt High Esquimalt High	1919 1995 1995	Feb-21 Dec-19 Dec-19 Dec-19	1 1 1	Sink Water Fountain Water Fountain	Servery-1021A Change-1058 Change-1056 Corridor-1036	0.001 0.001 0.001	No No No	Lead filter installed with lead free fixture Lead filter installed with lead free fixture Lead filter installed with lead free fixture	Enformation is provided to School staff w Enformation is provided to School staff w Enformation is provided to School staff w Enformation is provided to School staff w	None. None. None.	Jul-21 Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21
61 61	06161048 06161048 06151048	Esquimalt High	1959 1987 1959	Dec-19	1	Water Filling Station Sink	Kitchen-1094	0.001 0.004 0.001	No No No	Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur	Information is provided to School staff w Information is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21
61 61	06161048 06161048	Esquimalt High Esquimalt High Esquimalt High Esquimalt High	1959 1959	Dec-19 Dec-19 Aug-19 Dec-19	1 2	Sink Sink Water Filling Station	Lunch-1098 Staff-1118 Medical-1115	0.001 0.003	No No	Lead filter installed with lead free fixtur 30 Sec flush before use until filter can be	Information is provided to School staff w Information is provided to School staff w	None. None.		30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21
61 61 61	06161048 06161048 06161048	Esquimalt High Esquimalt High Esquimalt High Esquimalt High Esquimalt High	1959 1966 1966	Dec-19 Oct-19 Oct-19	1 2 1	Water Filling Station Sink Sink	Corridor-2011 Foods-2042 Foods-2042	0.003 0.003 0.001	No No No	Lead filter installed with lead free fixtur 30 Sec flush before use until filter can be Lead filter installed with lead free fixture	Information is provided to School staff w Information is provided to School staff w Information is provided to School staff w	None. None.	Jul-21	30-Mar-21
61 61 51	06161048 06161048 06161048	Esquimalt High Esquimalt High Esquimalt High	1966 1966 1966	Oct-19 Oct-19 Oct-19	1	Sink Sink Sink	Foods-2042 Foods-2042 Foods-2042	0.001 0.001	No No No	Lead filter installed with lead free fixtun Lead filter installed with lead free fixtun Lead filter installed with lead free fixtun		None. None.	Jul-21 Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21
61 61	06161048 06161048	Esquimalt High Esquimalt High	1966 1959	Oct-19 Dec-19	1	Sink Water Fountain	Foods-2042 Corridor-3009	0.002 0.001	No No	Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur	Information is provided to School staff w Information is provided to School staff w	None. None.	Jul-21	30-Mar-21
61 61	06161048 06161048 06161048	Esquimalt High Esquimalt High Esquimalt High Esquimalt High	1959 1967 1967	Dec-19 Dec-19 Oct-19 Oct-19	1 1 1	Water Foundam Water Filling Station Sink	Corridor-3028 Foods-3031	0.001 0.002	NO NO NO	Lead filter installed with lead free fixtun Lead filter installed with lead free fixtun Lead filter installed with lead free fixtun	Information is provided to School staff w Information is provided to School staff w Information is provided to School staff w Information is provided to School staff w	None. None. None.	Jul-21 Jul-21 Jul-21	30-Mar-21 30-Mar-21
61 61 61	06161048 06161048 06161048	Esquimalt High	1967 1967 1967	Oct-19	1 1 1	Sink Sink Sink	Foods-3031 Foods-3031 Foods-3031	0.003 0.003 0.002	No No No	Lead filter installed with lead free fixtun Lead filter installed with lead free fixtun Lead filter installed with lead free fixtun	Information is provided to School staff w Information is provided to School staff w Information is provided to School staff w	None. None.	Jul-21 Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21
61 61	06161048 06161048	Esquimalt High Esquimalt High Esquimalt High Esquimalt High	1967 1967	Oct-19 Oct-19 Oct-19	1	Sink Sink Water Fountain	Foods-3031 Foods-3031 Foods-3031 Corridor-2016	0.001 0.002	No No	Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur Lead filter installed with lead free fixtur	Information is provided to School staff w Information is provided to School staff w	None.		30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21
61 61	06161048 06161048	Esquimait High Esquimait High Esquimait High	1900 1987 1987	Oct-19 Dec-19 Dec-19 Dec-19 Dec-19	1 1 1	Sink Other	Kitchen-1094 Kitchen-1094	0.001 0.004 0.003	NO NO NO	Lead filter installed with lead free fixture Lead filter installed with lead free fixture Lead filter installed with lead free fixture	Information is provided to School staff w information is provided to School staff w	None. None.	Jul-21	30-Mar-21
61 61 61	06161048 06161048 06161030	Esquimalt High Esquimalt High Frank Hobbs Elementary	1959 1987 1950	Apr-20 Aug-20 Jul-20	2 2 1	Sink Sink Water Fountain	Class-1100 Kitchen-1094 Corridor-1056	0.001 0.008 0.000	No Yes No	30 Sec flush before use until filter can be Sink has been shut off and labeled do no Lead filter installed with lead free fixture	Information is provided to School staff w Information is provided to School staff w Information is provided to School staff w	None. None. None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21 20 May 31
61 61	06161030 06161030 06161030	Frank Hobbs Elementary Frank Hobbs Elementary Frank Hobbs Elementary	1961 1961	Oct-18 Oct-18 Oct-19	2	Water Filling Station Sink Water Filling Station	Corridor-1075 Staff-1072 Corridor 1055	0.001 0.001	No No No	30 Sec flush before use until filter can b 30 Sec flush before use until filter can b 30 Sec flush before use until filter can b	Information is provided to School staff w Information is provided to School staff w Information is provided to School	None.	Jul-21	30-Mar-21 30-Mar-21 30-Mar-21
61 61	06161030 06161030	Frank Hobbs Elementary Frank Hobbs Elementary Frank Hobbs Elementary Frank Hobbs Elementary	1972 1964	Oct-18 Oct-18 Apr-19 Apr-20	2 1	Sink Water Filling Station	Class-0004 Corridor-1075 Class-1064	0.002	No	30 Sec flush before use until filter can be 30 Sec flush before use until filter can be Lead filter installed with lead free fixtur Sink has been shut off and labeled do no	Information is provided to School staff w	None. None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21
61 61	06161030 06161030 06161005	Frank Hobbs Elementary	1957	Apr-20	2 2 2 2	Sink Sink Water Filling Station	Class-1064 Kitchen-1016 Corridor-1000	0.007 0.001 0.000	Yes No No	Sink has been shut off and labeled do no 30 Sec flush before use until filter can be 30 Sec flush before use until filter can be	Information is provided to School staff w Information is provided to School staff w Information is provided to School staff w	None. None.	Jul-21 Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21
61 61 61	06161005 06161005 06161005	George Jay Elementary George Jay Elementary George Jay Elementary George Jay Elementary	1972 1909 1909 1956	Oct-18 Oct-18 Oct-18 Oct-18	2	Water Filling Station Water Filling Station Water Filling Station Water Filling Station	Corridor-1011 Corridor-1011 Corridor-1038	0.000 0.000 0.000	No No No	30 Sec flush before use until filter can be 30 Sec flush before use until filter can be 30 Sec flush before use until filter can be	Information is provided to School staff w Information is provided to School staff w Information is provided to School staff w	None. None.		30-Mar-21 30-Mar-21 30-Mar-21 30-Mar-21

SCHOOL FACILITY INFORMATION						TEST	INFORMATION			MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN			ADDITIONAL INFORMATION	
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period
61	06161005	George Jay Elementary	1962	Oct-18	2	Water Filling Station	Corridor-1045	0.001	No		e Information is provided to School staff w		Jul-21	30-Mar-21
61	06161005	George Jay Elementary George Jay Elementary	1909	Oct-18 Oct-18	2	Water Filling Station Water Filling Station	Corridor-2052 Corridor-2038	0.000	No	30 Sec flush before use until filter can b	e Information is provided to School staff w e Information is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21 30-Mar-21
	06161005	George Jay Elementary	1962	Oct-18	2	Water Filling Station	Corridor-2038	0.000	No	30 Sec flush before use until filter can b	e information is provided to School staff w	None.	Jul-21	30-Mar-21
61	06161005	George Jay Elementary	1909	Aug-19	1	Sink	Staff-2014	0.002	No	Lead filter installed with lead free fixtur	re Information is provided to School staff w	None.	Jul-21	30-Mar-21
61	06161005	George Jay Elementary	1909	Oct-18	2	Sink	Class-1020	0.001	No	30 Sec flush before use until filter can b	e Information is provided to School staff w	None.	Jul-21	30-Mar-21
61	06161005 06161038	George Jay Elementary Glanford Middle School	1972	Oct-18 Feb-20		Sink Water Fountain	Kitchen-1003 Corridor-1074	0.001	NO		e Information is provided to School staff w reInformation is provided to School staff w		Jul-21 Jul-21	30-Mar-21 30-Mar-21
61	06161038	Glanford Middle School			······	Water Fountain	Corridor-1055	0.000	No	Lead filter installed with lead free fixtur	reinformation is provided to School staff w	None.	Jul-21	30-Mar-21
61	06161038 06161038	Glanford Middle School	2004	Feb-20	1	Water Fountain	Gym-1070 Corridor-1083	0.001	No	Load filter installed with load free firtur	relation is provided to School staff w	None	Jul-21	30-Mar-21
61	06161038	Glanford Middle School	1955	Feb-20	1	Water Fountain		0.001	No	Lead filter installed with lead free fixtur	re Information is provided to School staff w	None.	Jul-21	30-Mar-21
61	06161038	Glanford Middle School	2001	Fob 20	······	Water Fountain	Corridor-1033	0.002	No	Lead filter installed with lead free fixtur	reinformation is provided to School staff w	None.	Jul-21	30-Mar-21
61	06161038	Glanford Middle School		Feb-20		Sink	Staff-1039 Foods-1059	0.004	No	Lead filter installed with lead free fixtur	reinformation is provided to School staff w	None.	Jul-21	30-Mar-21
61	06161038	Glanford Middle School	2004	Feb-20	1	Sink	Foods-1059	0.005	No	Lead filter installed with lead free fixtur	e Information is provided to School staff w	None.	Jul-21	30-Mar-21
61	06161038	Glanford Middle School	2004	Feb-20	1	Sink	Foods-1059	0.001	No	Lead filter installed with lead free fixtur	e Information is provided to School staff w	None.	Jul-21	30-Mar-21
61	06161038	Glanford Middle School Glanford Middle School	2004	Feb-20 Feb-20 Feb-20	1	Sink	Foods-1059 Foods-1059	0.002	No		reInformation is provided to School staff w		Jul-21	30-Mar-21
61	06161038	Glanford Middle School	2004	Feb-20	1	Sink	Foods-1059 Foods-1059	0.004	NO		reinformation is provided to School staff w		Jul-21 Jul-21	30-Mar-21
	06161038	Glanford Middle School	2004	Feb-20	1	Sink	Foods-1059	0.002	No		reInformation is provided to School staff w		Jul-21	30-Mar-21
61	06161038	Glanford Middle School Glanford Middle School	2004	Feb-20	1	Sink	Foods-1059	0.001	No	Lead filter installed with lead free fixtur	reinformation is provided to School staff w	None.	Jul-21	30-Mar-21
61	06161038			Feb-20		Sink	Foods-1059	0.003	No	Lead filter installed with lead free fixtur	re Information is provided to School staff w	None.	Jul-21	30-Mar-21
61 64	06161038	Glanford Middle School		Feb-20		Sink Water Equatoia	Portable-0027	0.001	NO		reinformation is provided to School staff w		Jul-21	30-Mar-21 30-Mar-21
61	06161038 06161038	Glanford Middle School Glanford Middle School	•••••	Feb-20 Feb-20	·····	Water Fountain Sink	Portable-0027 Portable-0033	0.000 0.004	NO	Lead filter installed with lead free fixtur	re Information is provided to School staff w re Information is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21
51	06161038	Glanford Middle School		Feb-20		Water Fountain	Portable-0033	0.002	No		reInformation is provided to School staff w		Jul-21	30-Mar-21
51	06161038	Glanford Middle School		Feb-20		Sink	Medical-1086	0.001	No	Lead filter installed with lead free fixtur	re Information is provided to School staff w	None.	Jul-21	30-Mar-21
61	06161039	Gordon Head Middle School	2006	Dec-19	······	Water Filling Station	Vestibule-1119	0.001	No	Lead filter installed with lead free fixtur	e Information is provided to School staff w	None.	Jul-21	30-Mar-21
	06161039	Gordon nedd middie Senoor		Dec-19		Water Filling Station	Corridor-1027	0.000	NO	Lead filter installed with lead free fixtur	reinformation is provided to School staff w	None.	Jui-21	30-Mar-21
51	06161039	Gordon Head Middle School	1963	Dec-19 Dec-19	1	Water Filling Station	Corridor-1027	0.001	No		reinformation is provided to School staff w	None.	Jul-21	30-Mar-21
61	06161039	Gordon Head Middle School	1981	Dec-19	1	Water Filling Station Sink	Corridor-1041	0.002	No	Lead filter installed with lead free fixtur	re Information is provided to School staff w	None.	Jul-21	30-Mar-21
61	06161039	Gordon Head Middle School	1976	Dec-19	1		Staff-1086	0.002	No	Lead filter installed with lead free fixtur	reInformation is provided to School staff w	None.	Jul-21	30-Mar-21 30-Mar-71
51 54	06161039 06161039	Gordon Head Middle School Gordon Head Middle School	1955	Dec-19	1	Sink Sink	Servery-1115 Foods-1103	0.000	No	Lead filter installed with lead free fixtur	reinformation is provided to School staff w	None.	Jul-21 Jul-21	30-Mar-21
51	06161039	Gordon Head Middle School	1955 1955	Oct-19 Oct-19	1	Sink	Foods-1103	0.002	No		re Information is provided to School staff w re Information is provided to School staff w		Jul-21	30-Mar-21
51	06161039	Gordon Head Middle School	1955		1	Sink	Foods-1103	0.003	No	Lead filter installed with lead free fixtur	re Information is provided to School staff w	None.	Jul-21	30-Mar-21
61	06161039	Gordon Head Middle School	1955	Oct-19	1	Sink	Foods-1103	0.004	No	Lead filter installed with lead free fixtur	reInformation is provided to School staff w	None.	Jul-21	30-Mar-21
	06161039 06161039	Gordon Head Middle School Gordon Head Middle School	1955	Oct-19		Sink	Foods-1103 Foods-1103	0.004	No		re Information is provided to School staff w re Information is provided to School staff w		Jul-21	30-Mar-21 30-Mar-21
61	06161039	Gordon Head Middle School	1955 1955		·····	Sink Sink	Foods-1103	0.003	No	Lead filter installed with lead free fixtur	reinformation is provided to School staff w	None	Jul-21 Jul-21	30-Mar-21 30-Mar-21 30-Mar-21
61	06161039	Gordon Head Middle School	1955 1955 1955	Oct-19	1	Sink	Foods-1103	0.004	No		re Information is provided to School staff w		Jul-21	30-Mar-21
61	06161039	Gordon Head Middle School	1955	Oct-19	1	Sink	Foods-1103	0.004	No	Lead filter installed with lead free fixtur	reInformation is provided to School staff w	None.	Jul-21	30-Mar-21
61	06161039	Gordon Head Middle School		Dec-19	······	Water Fountain	Vestibule-1119	0.000	No	Lead filter installed with lead free fixtur	e Information is provided to School staff w	None.	Jul-21	30-Mar-21
61	06161052	Hillcrest Elementary	1976	Apr-20 Aug-19	1	Water Fountain	Medical-1120 Corridor-0142	0.001	NO	Lead filter installed with lead free fixtur	reinformation is provided to School staff w	None.	Jui-21	30-Mar-21 30-Mar-21
61	06161052	Hillcrest Elementary	1965	Aug-19 Sep-17	2	Sink	Corridor-0142 Class-0003	0.003	No	30 Sec flush before use until filter can b	e Information is provided to School staff w	None.	Jul-21	30-Mar-21
61	06161052	Hillcrest Elementary	1965	Sep-17		Water Fountain	Corridor-0151	0.005	No	30 Sec flush before use until filter can b	e Information is provided to School staff w	None.	Jul-21	30-Mar-21
61	06161052	Hillcrest Elementary	1965	Aug-19	2	Sink	Medical-0158 Corridor-0131	0.003	No	30 Sec flush before use until filter can b	e Information is provided to School staff w	None.	Jul-21	30-Mar-21
61	06161052 06161052	Hillcrest Elementary Hillcrest Elementary	1968	Aug-20 Sen-17	1	Water Filling Station Sink	Corridor-0131 Staff-0104	0.005	No	Lead filter installed with lead free fixtur 30 Sec fluch before use until filter can be	e Information is provided to School staff w e Information is provided to School staff w	None.	Jul-21	30-Mar-21 30-Mar-21
61	06161052	Hillcrest Elementary	1968	Sep-17 Aug-19		Water Filling Station	Corridor-0218	0.000	No		reinformation is provided to school staff w		Jul-21 Jul-21	30-Mar-21 30-Mar-21
61	06161052	Hillcrest Elementary			2	Sink	Class-0135	0.003	No		e Information is provided to School staff w		Jul-21	30-Mar-21
61	06161052	Hillcrest Elementary	1965 1992 1952	Apr-20	1	Sink	Class-0111	0.001	No	Lead filter installed with lead free fixtur	reInformation is provided to School staff w	None.	Jul-21	30-Mar-21 30-Mar-21
61	06161033	James Bay Community	1952	Jan-19	1	Water Fountain	Corridor-1016	0.001	No	Lead filter installed with lead free fixtur	reInformation is provided to School staff w	None.	Jul-21	30-Mar-21