



2021/22 REPORT FOR TESTING LEAD CONTENT IN DRINKING WATER OF SCHOOL FACILITIES

School District Information		Health Authority (HA) Information	
SD No.	61	Region	Vancouver Island
SD Name	Greater Victoria	Contact Name	Stacey Sowa
SD Contact Name:	Justin Taylor	Contact Phone	stacey.sowa@viha.ca
SD Contact Phone:	250-881-4041	Report Submitted to HA	Yes
Report Date	3/15/2022	Report Submission Date	3/15/2022

[Click here to access the School Master List for Facility Names and Facility Codes](#)

SCHOOL FACILITY INFORMATION				TEST INFORMATION					MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN			ADDITIONAL INFORMATION		
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period
61	06161062	Arbutus Global Middle School	1969	Aug-20	1	Water Fountain	CORRIDOR-1079	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Aug-23	30-Mar-22
61	06161062	Arbutus Global Middle School	1969	Nov-19	1	Sink	STAFF-1004	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Nov-22	30-Mar-22
61	06161062	Arbutus Global Middle School	1969	Aug-19	1	Water Fountain	CORRIDOR-1040	0.004	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Aug-22	30-Mar-22
61	06161062	Arbutus Global Middle School	1969	Aug-20	1	Sink	FOODS-1035	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Aug-23	30-Mar-22
61	06161062	Arbutus Global Middle School	1969	Aug-20	1	Sink	FOODS-1035	0.002	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Aug-23	30-Mar-22
61	06161062	Arbutus Global Middle School	1969	Aug-20	2	Sink	FOODS-1035	0.001	No	30 Sec flush before use until filter can. Information is provided to School staf None.			Aug-23	30-Mar-22
61	06161062	Arbutus Global Middle School	1969	Oct-19	1	Sink	FOODS-1035	0.004	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct-22	30-Mar-22
61	06161062	Arbutus Global Middle School	1969	Aug-20	1	Sink	FOODS-1035	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Aug-23	30-Mar-22
61	06161062	Arbutus Global Middle School	1969	Aug-20	2	Sink	FOODS-1035	0.001	No	30 Sec flush before use until filter can. Information is provided to School staf None.			Aug-23	30-Mar-22
61	06161062	Arbutus Global Middle School	1969	Aug-20	1	Water Filling Station	CORRIDOR-1044	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Aug-23	30-Mar-22
61	06161062	Arbutus Global Middle School	1969	Nov-19	1	Water Fountain	CHANGE-0002	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Nov-22	30-Mar-22
61	06161062	Arbutus Global Middle School	1969	Nov-19	1	Water Fountain	CHANGE-0008	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Nov-22	30-Mar-22
61	06161062	Arbutus Global Middle School	1969	Aug-20	1	Sink	FOODS-1035	0.004	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Aug-23	30-Mar-22
61	06161062	Arbutus Global Middle School	1969	Aug-20	2	Sink	FOODS-1035	0.000	No	30 Sec flush before use until filter can. Information is provided to School staf None.			Aug-23	30-Mar-22
61	06161062	Arbutus Global Middle School	1969	Apr-20	2	Sink	KITCH-1060	0.003	No	30 Sec flush before use until filter can. Information is provided to School staf None.			Apr-23	30-Mar-22
61	06161062	Arbutus Global Middle School	1969	Oct-19	2	Sink	FOODS-1035	0.003	No	30 Sec flush before use until filter can. Information is provided to School staf None.			Oct-22	30-Mar-22
61	06161051	Braefoot Elementary	1970	Sep-20	1	Sink	KITCH-1037	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Sep-23	30-Mar-22
61	06161051	Braefoot Elementary	1970	May-19	1	Water Fountain	CORRIDOR-1043	0.004	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			May-22	30-Mar-22
61	06161051	Braefoot Elementary	1970	Sep-20	1	Water Filling Station	CORRIDOR-1043	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Sep-23	30-Mar-22
61	06161051	Braefoot Elementary	1970	Sep-20	1	Sink	STAFF-1024	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Sep-23	30-Mar-22
61	06161051	Braefoot Elementary	1970	May-19	1	Water Filling Station	CORRIDOR-1049	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			May-22	30-Mar-22
61	06161051	Braefoot Elementary	1970	Sep-17	2	Water Filling Station	CORRIDOR-2005	0.001	No	30 Sec flush before use until filter can. Information is provided to School staf None.			Sep-22	30-Mar-22
61	06161051	Braefoot Elementary	1970	May-19	1	Sink	CLASS-2008	0.004	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			May-22	30-Mar-22
61	06161051	Braefoot Elementary	1970	Sep-20	2	Sink	MEDIC-1005	0.002	No	30 Sec flush before use until filter can. Information is provided to School staf None.			Sep-23	30-Mar-22
61	06161051	Braefoot Elementary	1970	May-19	1	Water Filling Station	CORRIDOR-2005	0.005	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			May-22	30-Mar-22
61	06161047	Campus View Elementary	1964	Feb-22	1	Water Fountain	CORRIDOR-1050	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Feb-25	30-Mar-22
61	06161047	Campus View Elementary	1964	Feb-22	2	Water Fountain	CORRIDOR-1001	0.001	No	30 Sec flush before use until filter can. Information is provided to School staf None.			Feb-25	30-Mar-22
61	06161047	Campus View Elementary	1964	Feb-22	1	Sink	STAFF-1032	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Feb-25	30-Mar-22
61	06161047	Campus View Elementary	1964	Feb-22	1	Water Filling Station	CORRIDOR-1009	0.002	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Feb-25	30-Mar-22
61	06161047	Campus View Elementary	1964	Feb-22	1	Sink	PORTABLE-0013	0.004	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Feb-25	30-Mar-22
61	06161047	Campus View Elementary	1964	Aug-19	2	Water Fountain	PORTABLE-0025	0.002	No	30 Sec flush before use until filter can. Information is provided to School staf None.			Aug-22	30-Mar-22
61	06161047	Campus View Elementary	1964	Feb-22	2	Sink	PORTABLE-0025	0.003	No	30 Sec flush before use until filter can. Information is provided to School staf None.			Feb-25	30-Mar-22
61	06161047	Campus View Elementary	1964	Feb-22	2	Sink	PORTABLE-0068	0.003	No	30 Sec flush before use until filter can. Information is provided to School staf None.			Feb-25	30-Mar-22
61	06161047	Campus View Elementary	1964	Aug-19	2	Water Fountain	PORTABLE-0068	0.002	No	30 Sec flush before use until filter can. Information is provided to School staf None.			Aug-22	30-Mar-22
61	06161047	Campus View Elementary	1964	Feb-22	1	Sink	PORTABLE-0117	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Feb-25	30-Mar-22
61	06161025	Cedar Hill Middle	1931	Jan-20	1	Water Fountain	CORRIDOR-1088	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan-23	30-Mar-22
61	06161025	Cedar Hill Middle	1931	Jan-20	1	Sink	STAFF-1078	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan-23	30-Mar-22
61	06161025	Cedar Hill Middle	1931	Jan-20	1	Water Filling Station	CORRIDOR-1016	0.005	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan-23	30-Mar-22
61	06161025	Cedar Hill Middle	1931	Sep-20	1	Sink	KITCH-1020	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Sep-23	30-Mar-22
61	06161025	Cedar Hill Middle	1931	Jan-20	1	Water Filling Station	CORRIDOR-1063	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan-23	30-Mar-22
61	06161025	Cedar Hill Middle	1931	Jan-20	1	Water Fountain	CORRIDOR-1051	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan-23	30-Mar-22
61	06161025	Cedar Hill Middle	1931	Jan-20	1	Sink	FOODS-1056	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan-23	30-Mar-22
61	06161025	Cedar Hill Middle	1931	Jan-20	1	Sink	FOODS-1056	0.004	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan-23	30-Mar-22
61	06161025	Cedar Hill Middle	1931	Jan-20	1	Sink	FOODS-1056	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan-23	30-Mar-22
61	06161025	Cedar Hill Middle	1931	Jan-20	1	Sink	FOODS-1056	0.002	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan-23	30-Mar-22
61	06161025	Cedar Hill Middle	1931	Jan-20	1	Sink	FOODS-1056	0.002	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan-23	30-Mar-22
61	06161025	Cedar Hill Middle	1931	Jan-20	1	Sink	FOODS-1056	0.002	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan-23	30-Mar-22
61	06161025	Cedar Hill Middle	1931	Jan-20	1	Water Filling Station	CORRIDOR-2031	0.002	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan-23	30-Mar-22
61	06161025	Cedar Hill Middle	1931	Jan-20	1	Water Filling Station	CORRIDOR-2025	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan-23	30-Mar-22
61	06161025	Cedar Hill Middle	1931	Jan-20	1	Water Fountain	CORRIDOR-2003	0.004	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan-23	30-Mar-22
61	06161025	Cedar Hill Middle	1931	Jan-20	1	Sink	FOODS-1056	0.002	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan-23	30-Mar-22
61	06161025	Cedar Hill Middle	1931	Sep-20	1	Sink	FOODS-1056	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Sep-23	30-Mar-22
61	06161025	Cedar Hill Middle	1931	Sep-20	2	Sink	MEDICAL-1069	0.001	No	30 Sec flush before use until filter can. Information is provided to School staf None.			Sep-23	30-Mar-22
61	06161025	Cedar Hill Middle	1931	Dec-20	1	Sink	ROOM-2009	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Dec-23	30-Mar-22
61	06161035	Central Middle School	1953	Feb-22	1	Water Filling Station	LOBBY-1053	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Feb-25	30-Mar-22
61	06161035	Central Middle School	1953	Feb-22	1	Water Fountain	CAFÉ-1030	0.005	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Feb-25	30-Mar-22
61	06161035	Central Middle School	1953	Feb-22	1	Water Fountain	CORRIDOR-1023	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Feb-25	30-Mar-22
61	06161035	Central Middle School	1953	Feb-22	1	Water Fountain	CORRIDOR-2041	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Feb-25	30-Mar-22
61	06161035	Central Middle School	1953	Feb-22	1	Water Fountain	CORRIDOR-2016	0.002	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Feb-25	30-Mar-22
61	06161035	Central Middle School	1953	Feb-22	1	Water Filling Station	CORRIDOR-3019	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Feb-25	30-Mar-22

SCHOOL FACILITY INFORMATION				TEST INFORMATION						MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN			ADDITIONAL INFORMATION	
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period
61	06161018	Victoria High	1911	Oct-19	1	Sink	FOODS-1013	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct-22	30-Mar-22
61	06161018	Victoria High	1911	Dec-19	1	Sink	KITCH-2020	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Dec-22	30-Mar-22
61	06161018	Victoria High	1911	Dec-19	1	Water Fountain	GYM-0030	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Dec-22	30-Mar-22
61	06161004	Victoria West Elementary	1969	Dec-19	1	Water Filling Station	CORRIDOR-1064	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Dec-22	30-Mar-22
61	06161004	Victoria West Elementary	1969	Dec-19	1	Water Fountain	CORRIDOR-1064	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Dec-22	30-Mar-22
61	06161004	Victoria West Elementary	1969	Feb-21	1	Sink	MEDIC-1057	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Feb-24	30-Mar-22
61	06161004	Victoria West Elementary	1969	Dec-19	1	Sink	STAFF-1055	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Dec-22	30-Mar-22
61	06161004	Victoria West Elementary	1969	Dec-19	1	Water Fountain	CORRIDOR-1049	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Dec-22	30-Mar-22
61	06161004	Victoria West Elementary	1969	Dec-19	1	Water Filling Station	CORRIDOR-1049	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Dec-22	30-Mar-22
61	06161004	Victoria West Elementary	1969	Dec-19	1	Water Fountain	CORRIDOR-1032	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Dec-22	30-Mar-22
61	06161004	Victoria West Elementary	1969	Dec-19	1	Sink	ANNEX-A1001	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Dec-22	30-Mar-22
61	06161004	Victoria West Elementary	1969	Feb-21	1	Sink	KITCH-1038	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Feb-24	30-Mar-22
61	06161004	Victoria West Elementary	1969	Dec-19	1	Sink	KITCH-1038	0.002	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Dec-22	30-Mar-22
61	06161004	Victoria West Elementary	1969	Feb-21	1	Sink	KITCH-1038	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Feb-24	30-Mar-22
61	06161029	View Royal Elementary	1948	Jul-19	1	Sink	DAYCARE	0.002	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jul-22	30-Mar-22
61	06161029	View Royal Elementary	1948	Jul-19	1	Sink	DAYCARE	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jul-22	30-Mar-22
61	06161029	View Royal Elementary	1948	Oct-19	1	Water Filling Station	CORRIDOR-1065	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct-22	30-Mar-22
61	06161029	View Royal Elementary	1948	Oct-19	1	Sink	MEDIC-1007A	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct-22	30-Mar-22
61	06161029	View Royal Elementary	1948	Oct-19	1	Sink	STAFF-1042	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct-22	30-Mar-22
61	06161029	View Royal Elementary	1948	Oct-19	1	Water Filling Station	CORRIDOR-1019	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct-22	30-Mar-22
61	06161029	View Royal Elementary	1948	Oct-19	1	Sink	CLASS-0027	0.004	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct-22	30-Mar-22
61	06161029	View Royal Elementary	1948	Oct-19	1	Water Fountain	DAYCARE	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct-22	30-Mar-22
61	06161029	View Royal Elementary	1948	Oct-19	1	Water Fountain	CORRIDOR-1031	0.002	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct-22	30-Mar-22
61	06161029	View Royal Elementary	1948	Oct-19	1	Sink	KITCH-1044	0.002	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct-22	30-Mar-22
61	06161029	View Royal Elementary	1948	Oct-19	1	Sink	DAYCARE	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct-22	30-Mar-22