

Greater Victoria School District
Annual Water Sampling Report
Submitted to Ministry of Education and Child Care on February 28, 2025

School Name	School Identifier	Testing information					Result		Public Communication Plan
	Ministry Asset Number	Test Date (dd-mm-yyy)	Time of test (24hr clock)	Sample Type	Fixture Type	Fixture Location Description	Lead Result (mg/L)	Exceeds Maximum Acceptable Concentration	
	123456	11-12-2022	07:45:00	Flushed	CF	Classroom Faucet (CF) in room 104, first floor, facility 211.	0.0043	No	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
Arbutus Middle school	6161062	2/07/2025	10:40:00	First Draw	DW	room 1040	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Arbutus Middle school	6161062	2/07/2025	10:40:00	Flushed	DW	room 1040	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Arbutus Middle school	6161062	2/07/2025	10:44:00	First Draw	DW	room 1044	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Arbutus Middle school	6161062	2/07/2025	10:44:00	Flushed	DW	room 1044	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Arbutus Middle school	6161062	2/07/2025	10:50:00	First Draw	DW	room 0002	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Arbutus Middle school	6161062	2/07/2025	10:50:00	Flushed	DW	room 0002	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Arbutus Middle school	6161062	2/07/2025	10:55:00	First Draw	DW	room 0008	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Arbutus Middle school	6161062	2/07/2025	10:55:00	Flushed	DW	room 0008	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Braefoot Elementary	6161051	27/01/2025	12:45:00	First Draw	KC	OSC 1	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Braefoot Elementary	6161051	27/01/2026	12:45:00	Flushed	KC	OSC 1	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Braefoot Elementary	6161051	27/01/2027	12:50:00	First Draw	KC	OSC 2	0.001	No	lead filter installed with lead free fixture,information provided to staff.
Braefoot Elementary	6161051	27/01/2028	12:50:00	Flushed	KC	OSC2	0.0008	No	lead filter installed with lead free fixture,information provided to staff.
Braefoot Elementary	6161051	27/01/2029	12:55:00	First Draw	KC	room 1037	0.002	No	lead filter installed with lead free fixture,information provided to staff.
Braefoot Elementary	6161051	27/01/2030	12:55:00	Flushed	KC	room 1037	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Braefoot Elementary	6161051	27/01/2031	13:00:00	First Draw	DW	outside library	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Braefoot Elementary	6161051	27/01/2032	13:00:00	Flushed	DW	outside library	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Braefoot Elementary	6161051	27/01/2033	13:05:00	First Draw	DW	hallway 2005	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Braefoot Elementary	6161051	27/01/2034	13:05:00	Flushed	DW	hallway 2005	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Campus View Elementary	6161047	07/02/2025	09:00:00	First Draw	CF	portable a	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Campus View Elementary	6161047	07/02/2025	09:00:00	Flushed	CF	portable a	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Campus View Elementary	6161047	07/02/2025	09:05:00	First Draw	CF	portable b	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Campus View Elementary	6161047	07/02/2025	09:05:00	Flushed	CF	portable b	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Campus View Elementary	6161047	07/02/2025	09:10:00	First Draw	CF	portable c	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Campus View Elementary	6161047	07/02/2025	09:10:00	Flushed	CF	portable c	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Campus View Elementary	6161047	07/02/2025	09:15:00	First Draw	CF	portable d	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Campus View Elementary	6161047	07/02/2025	09:15:00	Flushed	CF	portable d	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Cedar Hill Middle	6161025	02/11/2025	09:00:00	First Draw	CF	foods room # 8	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Cedar Hill Middle	6161025	02/11/2025	09:00:00	Flushed	CF	foods room # 8	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Cedar Hill Middle	6161025	02/11/2025	09:05:00	First Draw	CF	foods room # 9	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Cedar Hill Middle	6161025	02/11/2025	09:05:00	Flushed	CF	foods room # 9	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Cedar Hill Middle	6161025	02/11/2025	09:10:00	First Draw	CF	foods room # 10	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Cedar Hill Middle	6161025	02/11/2025	09:10:00	Flushed	CF	foods room # 10	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Cedar Hill Middle	6161025	02/11/2025	09:15:00	First Draw	CF	foods room # 12	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Cedar Hill Middle	6161025	02/11/2025	09:15:00	Flushed	CF	foods room # 12	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Cedar Hill Middle	6161025	02/11/2025	09:20:00	First Draw	CF	foods room # 14	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Cedar Hill Middle	6161025	02/11/2025	09:20:00	Flushed	CF	foods room # 14	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Central Middle	6161035	27/01/2025	10:00:00	First Draw	CF	foods room # 10	0.0012	No	lead filter installed with lead free fixture,information provided to staff.
Central Middle	6161035	27/01/2025	10:00:00	Flushed	CF	foods room # 10	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Central Middle	6161035	27/01/2025	10:05:00	First Draw	CF	foods room # 11	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Central Middle	6161035	27/01/2025	10:05:00	Flushed	CF	foods room # 11	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Central Middle	6161035	27/01/2025	10:10:00	First Draw	CF	foods room # 12	0.0014	No	lead filter installed with lead free fixture,information provided to staff.
Central Middle	6161035	27/01/2025	10:10:00	Flushed	CF	foods room # 12	0.0006	No	lead filter installed with lead free fixture,information provided to staff.

Greater Victoria School District
Annual Water Sampling Report
Submitted to Ministry of Education and Child Care on February 28, 2025

School Name	School Identifier	Testing information					Result		Public Communication Plan
	Ministry Asset Number	Test Date (dd-mm-yyy)	Time of test (24hr clock)	Sample Type	Fixture Type	Fixture Location Description	Lead Result (mg/L)	Exceeds Maximum Acceptable Concentration	
Central Middle	6161035	27/01/2025	10:15:00	First Draw	CF	foods room # 13	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Central Middle	6161035	27/01/2025	10:15:00	Flushed	CF	foods room # 13	0.0007	No	lead filter installed with lead free fixture,information provided to staff.
Central Middle	6161035	27/01/2025	10:20:00	First Draw	CF	foods room # 14	0.0046	No	lead filter installed with lead free fixture,information provided to staff.
Central Middle	6161035	27/01/2025	10:20:00	Flushed	CF	foods room # 14	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Cloverdale Elementary	6161019	25/02/2025	10:00:00	First Draw	KC	hallway 1030	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Cloverdale Elementary	6161019	25/02/2025	10:00:00	Flushed	KC	hallway 1030	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Cloverdale Elementary	6161019	25/02/2025	10:05:00	First Draw	BS	hallway 1002	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Cloverdale Elementary	6161019	25/02/2025	10:05:00	Flushed	BS	hallway 1002	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Cloverdale Elementary	6161019	25/02/2025	10:10:00	First Draw	KC	staff room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Cloverdale Elementary	6161019	25/02/2025	10:10:00	Flushed	KC	staff room	0.0007	No	lead filter installed with lead free fixture,information provided to staff.
Cloverdale Elementary	6161019	25/02/2025	10:15:00	First Draw	BS	hallway 2017	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Cloverdale Elementary	6161019	25/02/2025	10:15:00	Flushed	BS	hallway 2017	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Cloverdale Elementary	6161019	25/02/2025	10:20:00	First Draw	KC	OSC	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Cloverdale Elementary	6161019	25/02/2025	10:20:00	Flushed	KC	OSC	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Colquitz Middle	6161068	21/01/25	07:00:00	First Draw	BS	hallway 1050	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Colquitz Middle	6161068	21/01/25	07:00:00	Flushed	BS	hallway 1050	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Colquitz Middle	6161068	21/01/25	07:05:00	First Draw	BS	hallway 1003	0.001	No	lead filter installed with lead free fixture,information provided to staff.
Colquitz Middle	6161068	21/01/25	07:05:00	Flushed	BS	hallway 1003	0.0008	No	lead filter installed with lead free fixture,information provided to staff.
Colquitz Middle	6161068	21/01/25	07:10:00	First Draw	KC	room 1013	0.0012	No	lead filter installed with lead free fixture,information provided to staff.
Colquitz Middle	6161068	21/01/25	07:10:00	Flushed	KC	room 1013	0.0009	No	lead filter installed with lead free fixture,information provided to staff.
Colquitz Middle	6161068	21/01/25	07:15:00	First Draw	KC	room 1079	0.0013	No	lead filter installed with lead free fixture,information provided to staff.
Colquitz Middle	6161068	21/01/25	07:15:00	Flushed	LF	room 1079	0.0011	No	lead filter installed with lead free fixture,information provided to staff.
Craigflower Elementary	6161010	7/2/2025	07:00:00	First Draw	KC	room 1003	0.0007	No	lead filter installed with lead free fixture,information provided to staff.
Craigflower Elementary	6161010	7/2/2025	07:00:00	Flushed	KC	room 1003	0.0008	No	lead filter installed with lead free fixture,information provided to staff.
Craigflower Elementary	6161010	7/2/2025	07:05:00	First Draw	BS	outside gym	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Craigflower Elementary	6161010	7/2/2025	07:05:00	Flushed	BS	outside gym	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Craigflower Elementary	6161010	7/2/2025	07:10:00	First Draw	BS	hallway 2023	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Craigflower Elementary	6161010	7/2/2025	07:10:00	Flushed	BS	hallway 2023	0.0011	No	lead filter installed with lead free fixture,information provided to staff.
Doncaster Elementary	6161028	27/01/2025	11:20:00	First Draw	KC	OSC 1	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Doncaster Elementary	6161028	27/01/2025	11:20:00	Flushed	KC	OSC 1	0.0007	No	lead filter installed with lead free fixture,information provided to staff.
Doncaster Elementary	6161028	27/01/2025	11:25:00	First Draw	KC	OSC 2	0.0023	No	lead filter installed with lead free fixture,information provided to staff.
Doncaster Elementary	6161028	27/01/2025	11:25:00	Flushed	KC	OSC 2	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Doncaster Elementary	6161028	27/01/2025	11:30:00	First Draw	BS	hallway 1036	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Doncaster Elementary	6161028	27/01/2025	11:30:00	Flushed	BS	hallway 1036	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Doncaster Elementary	6161028	27/01/2025	11:35:00	First Draw	BS	hallway 1037	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Doncaster Elementary	6161028	27/01/2025	11:35:00	Flushed	BS	hallway 1037	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Doncaster Elementary	6161028	27/01/2025	11:40:00	First Draw	BS	hallway 1059	0.0013	No	lead filter installed with lead free fixture,information provided to staff.
Doncaster Elementary	6161028	27/01/2025	11:40:00	Flushed	BS	hallway 1059	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
EagleView Elementary	6161067	29/01/2025	13:00:00	First Draw	KC	room 1004	0.0012	No	lead filter installed with lead free fixture,information provided to staff.
EagleView Elementary	6161067	29/01/2025	13:00:00	Flushed	KC	room 1004	0.002	No	lead filter installed with lead free fixture,information provided to staff.
EagleView Elementary	6161067	29/01/2025	13:05:00	First Draw	CF	room 106	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
EagleView Elementary	6161067	29/01/2025	13:05:00	Flushed	CF	room 106	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
EagleView Elementary	6161067	29/01/2025	13:10:00	First Draw	CF	room 1044	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
EagleView Elementary	6161067	29/01/2025	13:10:00	Flushed	CF	room 1044	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
EagleView Elementary	6161067	29/01/2025	13:15:00	First Draw	CF	room 1043	0.0011	No	lead filter installed with lead free fixture,information provided to staff.
EagleView Elementary	6161067	29/01/2025	13:15:00	Flushed	CF	room 1043	0.0009	No	lead filter installed with lead free fixture,information provided to staff.
EagleView Elementary	6161067	29/01/2025	13:20:00	First Draw	CF	room 1042	0.0007	No	lead filter installed with lead free fixture,information provided to staff.

Greater Victoria School District
Annual Water Sampling Report
Submitted to Ministry of Education and Child Care on February 28, 2025

School Name	School Identifier	Testing information					Result		Public Communication Plan
	Ministry Asset Number	Test Date (dd-mm-yyy)	Time of test (24hr clock)	Sample Type	Fixture Type	Fixture Location Description	Lead Result (mg/L)	Exceeds Maximum Acceptable Concentration	
EagleView Elementary	6161067	29/01/2025	13:20:00	Flushed	CF	room 1042	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
EagleView Elementary	6161067	29/01/2025	13:25:00	First Draw	CF	daycare #1	0.0007	No	lead filter installed with lead free fixture,information provided to staff.
EagleView Elementary	6161067	29/01/2025	13:25:00	Flushed	CF	daycare#1	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
EagleView Elementary	6161067	29/01/2025	13:30:00	First Draw	KC	daycare#2	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
EagleView Elementary	6161067	29/01/2025	13:30:00	Flushed	KC	daycare#2	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
EagleView Elementary	6161067	29/01/2025	13:35:00	First Draw	KC	daycare kitchen	0.0007	No	lead filter installed with lead free fixture,information provided to staff.
EagleView Elementary	6161067	29/01/2025	13:35:00	Flushed	KC	daycare kitchen	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Macualay Elementary	6161040	29/01/2025	08:00:00	First Draw	KC	studio 2	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Macualay Elementary	6161040	29/01/2025	08:00:00	Flushed	KC	studio 2	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Macualay Elementary	6161040	29/01/2025	08:05:00	First Draw	KC	studio 1	0.0011	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Macualay Elementary	6161040	29/01/2025	08:05:00	Flushed	KC	studio 1	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Macualay Elementary	6161040	29/01/2025	08:10:00	First Draw	BS	hallway 2008	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Macualay Elementary	6161040	29/01/2025	08:10:00	Flushed	BS	hallway 2008	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Macualay Elementary	6161040	29/01/2025	08:15:00	First Draw	BS	hallway 2037	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Macualay Elementary	6161040	29/01/2025	08:15:00	Flushed	BS	hallway 2037	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Macualay Elementary	6161040	29/01/2025	08:20:00	First Draw	BS	hallway 1045	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Macualay Elementary	6161040	29/01/2025	08:20:00	Flushed	BS	hallway 1045	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Marigold Elementary	6161046	19/01/2025	11:20:00	First Draw	KC	studio 1	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Marigold Elementary	6161046	19/01/2025	11:20:00	Flushed	KC	studio 1	0.0008	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Marigold Elementary	6161046	19/01/2025	11:25:00	First Draw	KC	studio 2	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Marigold Elementary	6161046	19/01/2025	11:25:00	Flushed	KC	studio 2	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Marigold Elementary	6161046	19/01/2025	11:30:00	First Draw	BS	outside room 2	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Marigold Elementary	6161046	19/01/2025	11:30:00	Flushed	BS	outside room 2	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Marigold Elementary	6161046	19/01/2025	11:35:00	First Draw	BS	hallway 1046	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Marigold Elementary	6161046	19/01/2025	11:35:00	Flushed	BS	hallway 1046	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Marigold Elementary	6161046	19/01/2025	11:40:00	First Draw	BS	outside room 7	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Marigold Elementary	6161046	19/01/2025	11:40:00	Flushed	BS	outside room 7	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Quadra Elementary	6161016	11/02/2025	11:20:00	First Draw	CF	room 2004	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Quadra Elementary	6161016	11/02/2025	11:20:00	Flushed	CF	room 2004	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Quadra Elementary	6161016	11/02/2025	11:25:00	First Draw	CF	room 2006	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Quadra Elementary	6161016	11/02/2025	11:25:00	Flushed	CF	room 2006	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Quadra Elementary	6161016	11/02/2025	11:30:00	First Draw	CF	room 2001	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Quadra Elementary	6161016	11/02/2025	11:30:00	Flushed	CF	room 2001	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Quadra Elementary	6161016	11/02/2025	11:35:00	First Draw	CF	room 2025	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Quadra Elementary	6161016	11/02/2025	11:35:00	Flushed	CF	room 2025	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Willows Elementary	6161021	14/2/2025	09:50:00	First Draw	BS	hallway 2028	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Willows Elementary	6161021	14/2/2025	09:50:00	Flushed	BS	hallway 2028	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Willows Elementary	6161021	14/2/2025	10:00:00	First Draw	BS	hallway 2016	0.001	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Willows Elementary	6161021	14/2/2025	10:00:00	Flushed	BS	hallway 2016	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Willows Elementary	6161021	14/2/2025	10:10:00	First Draw	KC	staff room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Ecole Willows Elementary	6161021	14/2/2025	10:10:00	Flushed	KC	staff room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Esquimalt High	6161048	29/01/2025	09:00:00	First Draw	CF	foodsroom flt# 11	0.0008	No	lead filter installed with lead free fixture,information provided to staff.
Esquimalt High	6161048	29/01/2025	09:00:00	Flushed	CF	foodsroom flt# 11	0.001	No	lead filter installed with lead free fixture,information provided to staff.
Esquimalt High	6161048	29/01/2025	09:05:00	First Draw	CF	foodsroom flt# 12	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Esquimalt High	6161048	29/01/2025	09:05:00	Flushed	CF	foodsroom flt# 12	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Esquimalt High	6161048	29/01/2025	09:10:00	First Draw	CF	foodsroom flt# 13	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Esquimalt High	6161048	29/01/2025	09:10:00	Flushed	CF	foodsroom flt# 13	0.007	Yes	lead filter installed with lead free fixture,information provided to staff.

Greater Victoria School District
Annual Water Sampling Report
Submitted to Ministry of Education and Child Care on February 28, 2025

School Name	School Identifier	Testing information					Result		Public Communication Plan
	Ministry Asset Number	Test Date (dd-mm-yyy)	Time of test (24hr clock)	Sample Type	Fixture Type	Fixture Location Description	Lead Result (mg/L)	Exceeds Maximum Acceptable Concentration	
Esquimalt High	6161048	29/01/2025	09:15:00	First Draw	CF	foodsroom flt# 15	0.0011	No	lead filter installed with lead free fixture,information provided to staff.
Esquimalt High	6161048	29/01/2025	09:15:00	Flushed	CF	foodsroom flt# 15	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Esquimalt High	6161048	29/01/2025	09:20:00	First Draw	CF	foodsroom flt# 16	0.0009	No	lead filter installed with lead free fixture,information provided to staff.
Esquimalt High	6161048	29/01/2025	09:20:00	Flushed	CF	foodsroom flt# 16	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Esquimalt High	6161048	29/01/2025	09:25:00	First Draw	CF	foodsroom flt# 22	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Esquimalt High	6161048	29/01/2025	09:25:00	Flushed	CF	foodsroom flt# 22	0.0021	No	lead filter installed with lead free fixture,information provided to staff.
Esquimalt High	6161048	29/01/2025	09:30:00	First Draw	CF	foodsroom flt# 23	0.0017	No	lead filter installed with lead free fixture,information provided to staff.
Esquimalt High	6161048	29/01/2025	09:30:00	Flushed	CF	foodsroom flt# 23	0.0012	No	lead filter installed with lead free fixture,information provided to staff.
Esquimalt High	6161048	29/01/2025	09:35:00	First Draw	CF	foodsroom flt# 25	0.0012	No	lead filter installed with lead free fixture,information provided to staff.
Esquimalt High	6161048	29/01/2025	09:35:00	Flushed	CF	foodsroom flt# 25	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Esquimalt High	6161048	29/01/2025	09:40:00	First Draw	CF	foodsroom flt# 26	0.0032	No	lead filter installed with lead free fixture,information provided to staff.
Esquimalt High	6161048	29/01/2025	09:40:00	Flushed	CF	foodsroom flt# 26	0.0023	No	lead filter installed with lead free fixture,information provided to staff.
Frank Hobbs Elementary	6161030	07/02/2025	11:20:00	First Draw	CF	room 10	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Frank Hobbs Elementary	6161030	07/02/2025	11:20:00	Flushed	CF	room 10	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Frank Hobbs Elementary	6161030	07/02/2025	11:25:00	First Draw	BS	hallway 1077	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Frank Hobbs Elementary	6161030	07/02/2025	11:25:00	Flushed	BS	hallway 1077	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Frank Hobbs Elementary	6161030	07/02/2025	11:30:00	First Draw	KC	staff room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Frank Hobbs Elementary	6161030	07/02/2025	11:30:00	Flushed	KC	staff room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Frank Hobbs Elementary	6161030	07/02/2025	11:35:00	First Draw	CF	room 4	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Frank Hobbs Elementary	6161030	07/02/2025	11:35:00	Flushed	CF	room 4	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
George Jay Elementary	6161005	07/02/2025	12:45:00	First Draw	BS	hallway 1038	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
George Jay Elementary	6161005	07/02/2025	12:45:00	Flushed	BS	hallway 1038	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
George Jay Elementary	6161005	07/02/2025	12:50:00	First Draw	BS	hallway 1045	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
George Jay Elementary	6161005	07/02/2025	12:50:00	Flushed	BS	hallway 1045	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
George Jay Elementary	6161005	07/02/2025	12:55:00	First Draw	BS	hallway 2052	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
George Jay Elementary	6161005	07/02/2025	12:55:00	Flushed	BS	hallway 2052	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
George Jay Elementary	6161005	07/02/2025	13:00:00	First Draw	BS	hallway 2038	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
George Jay Elementary	6161005	07/02/2025	13:00:00	Flushed	BS	hallway 2038	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Glanford Middle	6161038	22/01/2025	12:30:00	First Draw	KC	foodsroom flt# 8	0.0014	No	lead filter installed with lead free fixture,information provided to staff.
Glanford Middle	6161038	22/01/2025	12:30:00	Flushed	KC	foodsroom flt# 8	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Glanford Middle	6161038	22/01/2025	12:35:00	First Draw	KC	foodsroom flt# 9	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Glanford Middle	6161038	22/01/2025	12:35:00	Flushed	KC	foodsroom flt# 9	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Glanford Middle	6161038	22/01/2025	12:40:00	First Draw	KC	foodsroom flt# 10	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Glanford Middle	6161038	22/01/2025	12:40:00	Flushed	KC	foodsroom flt# 10	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Glanford Middle	6161038	22/01/2025	12:45:00	First Draw	KC	foodsroom flt# 11	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Glanford Middle	6161038	22/01/2025	12:45:00	Flushed	KC	foodsroom flt# 11	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Glanford Middle	6161038	22/01/2025	12:50:00	First Draw	KC	foodsroom flt# 12	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Glanford Middle	6161038	22/01/2025	12:50:00	Flushed	KC	foodsroom flt# 12	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Glanford Middle	6161038	22/01/2025	12:55:00	First Draw	KC	foodsroom flt# 13	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Glanford Middle	6161038	22/01/2025	12:55:00	Flushed	KC	foodsroom flt# 13	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Gordon Head Middle School	6161039	21/01/2025	13:00:00	First Draw	CF	foodsroom flt# 8	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Gordon Head Middle School	6161039	21/01/2025	13:00:00	Flushed	CF	foodsroom flt# 8	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Gordon Head Middle School	6161039	21/01/2025	13:05:00	First Draw	CF	foodsroom flt# 9	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Gordon Head Middle School	6161039	21/01/2025	13:05:00	Flushed	CF	foodsroom flt# 9	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Gordon Head Middle School	6161039	21/01/2025	13:10:00	First Draw	CF	foodsroom flt# 10	0.0041	No	lead filter installed with lead free fixture,information provided to staff.
Gordon Head Middle School	6161039	21/01/2025	13:10:00	Flushed	CF	foodsroom flt# 10	0.0007	No	lead filter installed with lead free fixture,information provided to staff.
Gordon Head Middle School	6161039	21/01/2025	13:15:00	First Draw	CF	foodsroom flt# 11	0.0006	No	lead filter installed with lead free fixture,information provided to staff.

Greater Victoria School District
Annual Water Sampling Report
Submitted to Ministry of Education and Child Care on February 28, 2025

School Name	School Identifier	Testing information					Result		Public Communication Plan
	Ministry Asset Number	Test Date (dd-mm-yyy)	Time of test (24hr clock)	Sample Type	Fixture Type	Fixture Location Description	Lead Result (mg/L)	Exceeds Maximum Acceptable Concentration	
Gordon Head Middle School	6161039	21/01/2025	13:15:00	Flushed	CF	foodsroom flt# 11	0.0008	No	lead filter installed with lead free fixture,information provided to staff.
Gordon Head Middle School	6161039	21/01/2025	13:20:00	First Draw	CF	foodsroom flt# 13	0.0009	No	lead filter installed with lead free fixture,information provided to staff.
Gordon Head Middle School	6161039	21/01/2025	13:20:00	Flushed	CF	foodsroom flt# 13	0.001	No	lead filter installed with lead free fixture,information provided to staff.
Hillcrest Elementary	6161052	20/02/2025	11:30:00	First Draw	CF	room 3	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Hillcrest Elementary	6161052	20/02/2025	11:30:00	Flushed	CF	room 3	0.0045	No	lead filter installed with lead free fixture,information provided to staff.
Hillcrest Elementary	6161052	20/02/2025	11:40:00	First Draw	BS	hallway 131	0.0029	No	lead filter installed with lead free fixture,information provided to staff.
Hillcrest Elementary	6161052	20/02/2025	11:40:00	Flushed	BS	hallway 131	0.0021	No	lead filter installed with lead free fixture,information provided to staff.
Hillcrest Elementary	6161052	20/02/2025	11:50:00	First Draw	KC	staff room	0.0008	No	lead filter installed with lead free fixture,information provided to staff.
Hillcrest Elementary	6161052	20/02/2025	11:50:00	Flushed	KC	staff room	0.0009	No	lead filter installed with lead free fixture,information provided to staff.
Hillcrest Elementary	6161052	20/02/2025	12:35:00	First Draw	KC	studio 1	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Hillcrest Elementary	6161052	20/02/2025	12:35:00	Flushed	KC	studio 1	0.0007	No	lead filter installed with lead free fixture,information provided to staff.
Hillcrest Elementary	6161052	20/02/2025	12:40:00	First Draw	KC	studio 2	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Hillcrest Elementary	6161052	20/02/2025	12:40:00	Flushed	KC	studio 2	0.0008	No	lead filter installed with lead free fixture,information provided to staff.
James Bay Community	6161033	14/02/2025	10:45:00	First Draw	BS	hallway 1016	0.0023	No	lead filter installed with lead free fixture,information provided to staff.
James Bay Community	6161033	14/02/2025	10:45:00	Flushed	BS	hallway 1016	0.0023	No	lead filter installed with lead free fixture,information provided to staff.
James Bay Community	6161033	14/02/2025	10:50:00	First Draw	CF	room 3	0.0024	No	lead filter installed with lead free fixture,information provided to staff.
James Bay Community	6161033	14/02/2025	10:50:00	Flushed	CF	room 3	0.0024	No	lead filter installed with lead free fixture,information provided to staff.
James Bay Community	6161033	14/02/2025	10:55:00	First Draw	CF	room 1001	0.0022	No	lead filter installed with lead free fixture,information provided to staff.
James Bay Community	6161033	14/02/2025	10:55:00	Flushed	CF	room 1001	0.0021	No	lead filter installed with lead free fixture,information provided to staff.
James Bay Community	6161033	14/02/2025	11:00:00	First Draw	CF	room 12	0.0026	No	lead filter installed with lead free fixture,information provided to staff.
James Bay Community	6161033	14/02/2025	11:00:00	Flushed	CF	room 12	0.0025	No	lead filter installed with lead free fixture,information provided to staff.
James Bay Community	6161033	14/02/2025	11:05:00	First Draw	CF	room 1062	0.0017	No	lead filter installed with lead free fixture,information provided to staff.
James Bay Community	6161033	14/02/2025	11:05:00	Flushed	CF	room 1062	0.0019	No	lead filter installed with lead free fixture,information provided to staff.
James Bay Community	6161033	14/02/2025	11:10:00	First Draw	CF	OSC 1	0.0017	No	lead filter installed with lead free fixture,information provided to staff.
James Bay Community	6161033	14/02/2025	11:10:00	Flushed	CF	OSC 1	0.0023	No	lead filter installed with lead free fixture,information provided to staff.
Lake Hill Elementary	6161042	18/02/2025	07:20:00	First Draw	CF	room 106	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Lake Hill Elementary	6161042	18/02/2025	07:20:00	Flushed	CF	room 106	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Lake Hill Elementary	6161042	18/02/2025	07:25:00	First Draw	BS	front entrance	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Lake Hill Elementary	6161042	18/02/2025	07:25:00	Flushed	BS	front entrance	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Lake Hill Elementary	6161042	18/02/2025	07:30:00	First Draw	KC	gym kitchen	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Lake Hill Elementary	6161042	18/02/2025	07:30:00	Flushed	KC	gym kitchen	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Lambrick Park Secondary	6161064	18/02/2025	08:20:00	First Draw	CF	foodsroom flt# 9	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Lambrick Park Secondary	6161064	18/02/2025	08:20:00	Flushed	CF	foodsroom flt# 9	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Lambrick Park Secondary	6161064	18/02/2025	08:25:00	First Draw	CF	foodsroom flt# 10	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Lambrick Park Secondary	6161064	18/02/2025	08:25:00	Flushed	CF	foodsroom flt# 10	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Lambrick Park Secondary	6161064	18/02/2025	08:30:00	First Draw	CF	foodsroom flt# 11	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Lambrick Park Secondary	6161064	18/02/2025	08:30:00	Flushed	CF	foodsroom flt# 11	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Lambrick Park Secondary	6161064	18/02/2025	08:35:00	First Draw	CF	foodsroom flt# 13	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Lambrick Park Secondary	6161064	18/02/2025	08:35:00	Flushed	CF	foodsroom flt# 13	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Lambrick Park Secondary	6161064	18/02/2025	08:40:00	First Draw	CF	foodsroom flt# 14	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Lambrick Park Secondary	6161064	18/02/2025	08:40:00	Flushed	CF	foodsroom flt# 14	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Lansdowne Middle School	6161036	27/01/2025	07:00:00	First Draw	CF	foodsroom flt# 13	0.006	Yes	lead filter installed with lead free fixture,information provided to staff.
Lansdowne Middle School	6161036	27/01/2025	07:00:00	Flushed	CF	foodsroom flt# 13	0.0048	No	lead filter installed with lead free fixture,information provided to staff.
Lansdowne Middle School	6161036	27/01/2025	07:05:00	First Draw	CF	foodsroom flt# 15	0.0047	No	lead filter installed with lead free fixture,information provided to staff.
Lansdowne Middle School	6161036	27/01/2025	07:05:00	Flushed	CF	foodsroom flt# 15	0.004	No	lead filter installed with lead free fixture,information provided to staff.
Lansdowne Middle School	6161036	27/01/2025	07:10:00	First Draw	CF	foodsroom flt# 16	0.006	Yes	lead filter installed with lead free fixture,information provided to staff.
Lansdowne Middle School	6161036	27/01/2025	07:10:00	Flushed	CF	foodsroom flt# 16	0.006	Yes	lead filter installed with lead free fixture,information provided to staff.

Greater Victoria School District
Annual Water Sampling Report
Submitted to Ministry of Education and Child Care on February 28, 2025

School Name	School Identifier	Testing information					Result		Public Communication Plan
	Ministry Asset Number	Test Date (dd-mm-yyy)	Time of test (24hr clock)	Sample Type	Fixture Type	Fixture Location Description	Lead Result (mg/L)	Exceeds Maximum Acceptable Concentration	
Lansdowne Middle School	6161036	27/01/2025	07:15:00	First Draw	CF	foodsroom flt# 17	0.0043	No	lead filter installed with lead free fixture,information provided to staff.
Lansdowne Middle School	6161036	27/01/2025	07:15:00	Flushed	CF	foodsroom flt# 17	0.0041	No	lead filter installed with lead free fixture,information provided to staff.
Lansdowne Middle School	6161036	27/01/2025	07:20:00	First Draw	CF	foodsroom flt# 18	0.0049	No	lead filter installed with lead free fixture,information provided to staff.
Lansdowne Middle School	6161036	27/01/2025	07:20:00	Flushed	CF	foodsroom flt# 18	0.0033	No	lead filter installed with lead free fixture,information provided to staff.
Lansdowne Middle School	6161036	27/01/2025	07:25:00	First Draw	CF	foodsroom flt# 19	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Lansdowne Middle School	6161036	27/01/2025	07:25:00	Flushed	CF	foodsroom flt# 19	0.001	No	lead filter installed with lead free fixture,information provided to staff.
Lansdowne Middle School	6161036	22/02/2025	09:00:00	First Draw	CF	room 207	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Lansdowne Middle School	6161036	22/02/2025	09:00:00	Flushed	CF	room 207	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Lansdowne Middle School	6161036	22/02/2025	09:02:00	First Draw	CF	room 209	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Lansdowne Middle School	6161036	22/02/2025	09:02:00	Flushed	CF	room 209	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Margaret Jenkins Elementary	6161012	14/02/25	08:00:00	First Draw	BS	outside room # 007	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Margaret Jenkins Elementary	6161012	14/02/25	08:00:00	Flushed	BS	outside room # 007	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Margaret Jenkins Elementary	6161012	14/02/25	08:10:00	First Draw	BS	outside room # 2	0.0023	No	lead filter installed with lead free fixture,information provided to staff.
Margaret Jenkins Elementary	6161012	14/02/25	08:10:00	Flushed	BS	outside room # 2	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Margaret Jenkins Elementary	6161012	14/02/25	08:20:00	First Draw	BS	outside room # 1002	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Margaret Jenkins Elementary	6161012	14/02/25	08:20:00	Flushed	BS	outside room # 1002	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Margaret Jenkins Elementary	6161012	14/02/25	08:30:00	First Draw	KC	med room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Margaret Jenkins Elementary	6161012	14/02/25	08:30:00	Flushed	KC	med room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Margaret Jenkins Elementary	6161012	14/02/25	08:40:00	First Draw	KC	staff room	0.001	No	lead filter installed with lead free fixture,information provided to staff.
Margaret Jenkins Elementary	6161012	14/02/25	08:40:00	Flushed	KC	staff room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Margaret Jenkins Elementary	6161012	14/02/25	08:50:00	First Draw	CF	port 73 flt # 9	0.0019	No	lead filter installed with lead free fixture,information provided to staff.
Margaret Jenkins Elementary	6161012	14/02/25	08:50:00	Flushed	CF	port 73 flt # 9	0.0016	No	lead filter installed with lead free fixture,information provided to staff.
Margaret Jenkins Elementary	6161012	14/02/25	09:00:00	First Draw	BS	port 73 flt # 10	0.0015	No	lead filter installed with lead free fixture,information provided to staff.
Margaret Jenkins Elementary	6161012	14/02/25	09:00:00	Flushed	BS	port 73 flt # 10	0.0016	No	lead filter installed with lead free fixture,information provided to staff.
Margaret Jenkins Elementary	6161012	14/02/25	09:10:00	First Draw	BS	port 84 flt # 11	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Margaret Jenkins Elementary	6161012	14/02/25	09:10:00	Flushed	BS	port 84 flt # 11	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Margaret Jenkins Elementary	6161012	14/02/25	09:20:00	First Draw	CF	port 84 flt # 12	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Margaret Jenkins Elementary	6161012	14/02/25	09:20:00	Flushed	CF	port 84 flt # 12	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Mckenzie Elementary	6161027	10/01/2025	12:00:00	First Draw	CF	port 2 sink	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Mckenzie Elementary	6161027	10/01/2025	12:00:00	Flushed	CF	port 2 sink	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Mckenzie Elementary	6161027	10/01/2025	12:30:00	First Draw	KC	port 2 kitchen sink	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Mckenzie Elementary	6161027	10/01/2025	12:30:00	Flushed	KC	port 2 kitchen sink	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Mckenzie Elementary	6161027	10/01/2025	12:35:00	First Draw	CF	port 1 sink	0.0005	No	lead filter installed with lead free fixture,information provided to staff.
Mckenzie Elementary	6161027	10/01/2025	12:35:00	Flushed	CF	port 1 sink	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Mckenzie Elementary	6161027	10/01/2025	12:40:00	First Draw	KC	staff room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Mckenzie Elementary	6161027	10/01/2025	12:40:00	Flushed	KC	staff room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Monterey Middle	6161069	20/02/2025	09:30:00	First Draw	BS	hallway 1044	0.0008	No	lead filter installed with lead free fixture,information provided to staff.
Monterey Middle	6161069	20/02/2025	09:30:00	Flushed	BS	hallway 1044	0.0008	No	lead filter installed with lead free fixture,information provided to staff.
Monterey Middle	6161069	20/02/2025	09:40:00	First Draw	BS	hallway 1036	0.0018	No	lead filter installed with lead free fixture,information provided to staff.
Monterey Middle	6161069	20/02/2025	09:40:00	Flushed	BS	hallway 1036	0.0008	No	lead filter installed with lead free fixture,information provided to staff.
Monterey Middle	6161069	20/02/2025	09:50:00	First Draw	BS	hallway 1041	0.0018	No	lead filter installed with lead free fixture,information provided to staff.
Monterey Middle	6161069	20/02/2025	09:50:00	Flushed	BS	hallway 1041	0.0016	No	lead filter installed with lead free fixture,information provided to staff.
Monterey Middle	6161069	20/02/2025	10:20:00	First Draw	BS	hallway 1037	0.0012	No	lead filter installed with lead free fixture,information provided to staff.
Monterey Middle	6161069	20/02/2025	10:20:00	Flushed	BS	hallway 1037	0.001	No	lead filter installed with lead free fixture,information provided to staff.
Monterey Middle	6161069	20/02/2025	10:30:00	First Draw	BS	hallway 1056	0.0011	No	lead filter installed with lead free fixture,information provided to staff.
Monterey Middle	6161069	20/02/2025	10:30:00	Flushed	BS	hallway 1056	0.0011	No	lead filter installed with lead free fixture,information provided to staff.
Monterey Middle	6161069	20/02/2025	10:40:00	First Draw	KC	med room	0.001	No	lead filter installed with lead free fixture,information provided to staff.

Greater Victoria School District
Annual Water Sampling Report
Submitted to Ministry of Education and Child Care on February 28, 2025

School Name	School Identifier	Testing information					Result		Public Communication Plan
	Ministry Asset Number	Test Date (dd-mm-yyy)	Time of test (24hr clock)	Sample Type	Fixture Type	Fixture Location Description	Lead Result (mg/L)	Exceeds Maximum Acceptable Concentration	
Monterey Middle	6161069	20/02/2025	10:40:00	Flushed	KC	med room	0.0011	No	lead filter installed with lead free fixture,information provided to staff.
Monterey Middle	6161069	20/02/2025	10:50:00	First Draw	BS	hallway 2029	0.0009	No	lead filter installed with lead free fixture,information provided to staff.
Monterey Middle	6161069	20/02/2025	10:50:00	Flushed	BS	hallway 2029	0.0013	No	lead filter installed with lead free fixture,information provided to staff.
Mount Doug Secondary	6161049	20/02/2025	12:35:00	First Draw	KC	foodsroom flt# 15	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Mount Doug Secondary	6161049	20/02/2025	12:35:00	Flushed	KC	foodsroom flt# 15	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Mount Doug Secondary	6161049	20/02/2025	12:40:00	First Draw	KC	foodsroom flt# 16	0.0007	No	lead filter installed with lead free fixture,information provided to staff.
Mount Doug Secondary	6161049	20/02/2025	12:40:00	Flushed	KC	foodsroom flt# 16	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Mount Doug Secondary	6161049	20/02/2025	12:45:00	First Draw	KC	foodsroom flt# 17	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Mount Doug Secondary	6161049	20/02/2025	12:45:00	Flushed	KC	foodsroom flt# 17	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Mount Doug Secondary	6161049	20/02/2025	12:50:00	First Draw	KC	foodsroom flt# 19	0.0009	No	lead filter installed with lead free fixture,information provided to staff.
Mount Doug Secondary	6161049	20/02/2025	12:50:00	Flushed	KC	foodsroom flt# 19	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Mount Doug Secondary	6161049	20/02/2025	12:55:00	First Draw	KC	foodsroom flt# 20	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Mount Doug Secondary	6161049	20/02/2025	12:55:00	Flushed	KC	foodsroom flt# 20	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Mount Doug Secondary	6161049	20/02/2025	13:00:00	First Draw	KC	foodsroom flt# 21	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Mount Doug Secondary	6161049	20/02/2025	13:00:00	Flushed	KC	foodsroom flt# 21	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Mount Doug Secondary	6161049	20/02/2025	13:05:00	First Draw	KC	foodsroom flt# 23	0.0007	No	lead filter installed with lead free fixture,information provided to staff.
Mount Doug Secondary	6161049	20/02/2025	13:05:00	Flushed	KC	foodsroom flt# 23	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Mount Doug Secondary	6161049	22/02/2025	10:00:00	First Draw	KC	outside 207	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Mount Doug Secondary	6161049	22/02/2025	10:00:00	Flushed	KC	outside 207	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Mount Doug Secondary	6161049	22/02/2025	10:08:00	First Draw	KC	outside 209	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Mount Doug Secondary	6161049	22/02/2025	10:10:00	Flushed	KC	outside 209	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Northridge Elementary	6161054	19/02/25	09:20:00	First Draw	BS	hallway 1017	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Northridge Elementary	6161054	19/02/25	09:20:00	Flushed	BS	hallway 1017	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Northridge Elementary	6161054	19/02/25	09:30:00	First Draw	BS	hallway 1026	0.0008	No	lead filter installed with lead free fixture,information provided to staff.
Northridge Elementary	6161054	19/02/25	09:30:00	Flushed	BS	hallway 1026	0.0007	No	lead filter installed with lead free fixture,information provided to staff.
Northridge Elementary	6161054	19/02/25	09:35:00	First Draw	BS	hallway downstairs	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Northridge Elementary	6161054	19/02/25	09:35:00	Flushed	BS	hallway downstairs	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Oak Bay Secondary	6161024	20/02/2025	08:00:00	First Draw	CF	daycare flt# 1	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Oak Bay Secondary	6161024	20/02/2025	08:00:00	Flushed	CF	daycare flt# 1	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Oak Bay Secondary	6161024	20/02/2025	08:05:00	First Draw	CF	daycare flt# 2	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Oak Bay Secondary	6161024	20/02/2025	08:05:00	Flushed	CF	daycare flt# 2	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Oak Bay Secondary	6161024	20/02/2025	08:10:00	First Draw	CF	daycare flt# 3	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Oak Bay Secondary	6161024	20/02/2025	08:10:00	Flushed	CF	daycare flt# 3	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Oak Bay Secondary	6161024	20/02/2025	08:15:00	First Draw	CF	daycare flt# 4	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Oak Bay Secondary	6161024	20/02/2025	08:15:00	Flushed	CF	daycare flt# 4	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Oak Bay Secondary	6161024	20/02/2025	08:20:00	First Draw	CF	daycare flt# 5	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Oak Bay Secondary	6161024	20/02/2025	08:20:00	Flushed	CF	daycare flt# 5	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Oak Bay Secondary	6161024	20/02/2025	08:25:00	First Draw	KC	med room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Oak Bay Secondary	6161024	20/02/2025	08:25:00	Flushed	KC	med room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Oak Bay Secondary	6161024	20/02/2025	08:30:00	First Draw	CF	foodsroom flt# 28	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Oak Bay Secondary	6161024	20/02/2025	08:30:00	Flushed	CF	foodsroom flt# 28	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Oak Bay Secondary	6161024	20/02/2025	08:35:00	First Draw	CF	foodsroom flt# 29	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Oak Bay Secondary	6161024	20/02/2025	08:35:00	Flushed	CF	foodsroom flt# 29	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Oak Bay Secondary	6161024	20/02/2025	08:40:00	First Draw	CF	foodsroom flt# 30	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Oak Bay Secondary	6161024	20/02/2025	08:40:00	Flushed	CF	foodsroom flt# 30	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Oak Bay Secondary	6161024	20/02/2025	08:45:00	First Draw	CF	foodsroom flt# 31	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Oak Bay Secondary	6161024	20/02/2025	08:45:00	Flushed	CF	foodsroom flt# 31	0.0006	No	lead filter installed with lead free fixture,information provided to staff.

Greater Victoria School District Annual Water Sampling Report

[illegible]

Greater Victoria School District
Annual Water Sampling Report
Submitted to Ministry of Education and Child Care on February 28, 2025

School Name	School Identifier	Testing information					Result		Public Communication Plan
	Ministry Asset Number	Test Date (dd-mm-yyy)	Time of test (24hr clock)	Sample Type	Fixture Type	Fixture Location Description	Lead Result (mg/L)	Exceeds Maximum Acceptable Concentration	
Reynolds Secondary	6161057	07/02/2025	08:15:00	Flushed	KC	foodsroom flt# 11	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Reynolds Secondary	6161057	07/02/2025	08:50:00	First Draw	KC	foodsroom flt# 12	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Reynolds Secondary	6161057	07/02/2025	08:50:00	Flushed	KC	foodsroom flt# 12	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Reynolds Secondary	6161057	07/02/2025	09:00:00	First Draw	KC	foodsroom flt# 13	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Reynolds Secondary	6161057	07/02/2025	09:00:00	Flushed	KC	foodsroom flt# 13	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Reynolds Secondary	6161057	07/02/2025	00:05:00	First Draw	KC	foodsroom flt# 14	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Reynolds Secondary	6161057	07/02/2025	09:05:00	Flushed	KC	foodsroom flt# 14	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Reynolds Secondary	6161057	07/02/2025	09:10:00	First Draw	KC	foodsroom flt# 15	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Reynolds Secondary	6161057	07/02/2025	09:10:00	Flushed	KC	foodsroom flt# 15	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Reynolds Secondary	6161057	22/02/2025	11:05:00	First Draw	KC	room 115	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Reynolds Secondary	6161057	22/02/2025	11:05:00	Flushed	KC	room 115	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Reynolds Secondary	6161057	22/02/2025	11:10:00	First Draw	KC	room 1065	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Reynolds Secondary	6161057	22/02/2025	11:10:00	Flushed	KC	room 1065	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Lansdowne South Middle	6161060	27/01/2025	09:00:00	First Draw	KC	med room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Lansdowne South Middle	6161060	27/01/2025	09:00:00	Flushed	KC	med room	0.0009	No	lead filter installed with lead free fixture,information provided to staff.
Lansdowne South Middle	6161060	27/01/2025	09:05:00	First Draw	KC	staff room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Lansdowne South Middle	6161060	27/01/2025	09:05:00	Flushed	KC	staff room	0.0008	No	lead filter installed with lead free fixture,information provided to staff.
Lansdowne South Middle	6161060	27/01/2025	09:10:00	First Draw	BS	hallway 2030	0.0011	No	lead filter installed with lead free fixture,information provided to staff.
Lansdowne South Middle	6161060	27/01/2025	09:10:00	Flushed	BS	hallway 2030	0.0011	No	lead filter installed with lead free fixture,information provided to staff.
Rockheights Middle	6161056	22/01/2025	07:00:00	First Draw	BS	hallway 1037	0.0018	No	lead filter installed with lead free fixture,information provided to staff.
Rockheights Middle	6161056	22/01/2025	07:00:00	Flushed	BS	hallway 1037	0.0014	No	lead filter installed with lead free fixture,information provided to staff.
Rockheights Middle	6161056	22/01/2025	07:05:00	First Draw	BS	hallway 1039	0.0009	No	lead filter installed with lead free fixture,information provided to staff.
Rockheights Middle	6161056	22/01/2025	07:05:00	Flushed	BS	hallway 1039	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Rockheights Middle	6161056	22/01/2025	07:10:00	First Draw	BS	hallway 1061	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Rockheights Middle	6161056	22/01/2025	07:10:00	Flushed	BS	hallway 1061	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Rogers Elementary	6161066	14/02/25	13:30:00	First Draw	CF	daycare flt# 6	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Rogers Elementary	6161066	14/02/25	13:30:00	Flushed	CF	daycare flt# 6	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Rogers Elementary	6161066	14/02/25	13:35:00	First Draw	CF	daycare flt# 7	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Rogers Elementary	6161066	14/02/25	13:35:00	Flushed	CF	daycare flt# 7	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Rogers Elementary	6161066	14/02/25	13:40:00	First Draw	CF	daycare flt# 9	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Rogers Elementary	6161066	14/02/25	13:40:00	Flushed	CF	daycare flt# 9	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Rogers Elementary	6161066	14/02/25	13:45:00	First Draw	BS	hallway154	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Rogers Elementary	6161066	14/02/25	13:45:00	Flushed	BS	hallway154	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Rogers Elementary	6161066	14/02/25	13:50:00	First Draw	BS	hallway138	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Rogers Elementary	6161066	14/02/25	13:50:00	Flushed	BS	hallway138	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Rogers Elementary	6161066	14/02/25	13:55:00	First Draw	BS	hallway139	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Rogers Elementary	6161066	14/02/25	13:55:00	Flushed	BS	hallway139	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Rogers Elementary	6161066	14/02/25	14:00:00	First Draw	KC	multipurpose room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Rogers Elementary	6161066	14/02/25	14:00:00	Flushed	KC	multipurpose room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Shoreline Middle	6161058	21/01/2025	09:00:00	First Draw	CF	foodsroom flt# 7	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Shoreline Middle	6161058	21/01/2025	09:00:00	Flushed	CF	foodsroom flt# 7	0.0011	No	lead filter installed with lead free fixture,information provided to staff.
Shoreline Middle	6161058	21/01/2025	09:05:00	First Draw	CF	foodsroom flt# 8	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Shoreline Middle	6161058	21/01/2025	09:05:00	Flushed	CF	foodsroom flt# 8	0.001	No	lead filter installed with lead free fixture,information provided to staff.
Shoreline Middle	6161058	21/01/2025	09:10:00	First Draw	CF	foodsroom flt# 9	0.001	No	lead filter installed with lead free fixture,information provided to staff.
Shoreline Middle	6161058	21/01/2025	09:10:00	Flushed	CF	foodsroom flt# 9	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Shoreline Middle	6161058	21/01/2025	09:15:00	First Draw	CF	foodsroom flt# 10	0.0041	No	lead filter installed with lead free fixture,information provided to staff.
Shoreline Middle	6161058	21/01/2025	09:15:00	Flushed	CF	foodsroom flt# 10	0.0006	No	lead filter installed with lead free fixture,information provided to staff.

Greater Victoria School District
Annual Water Sampling Report
Submitted to Ministry of Education and Child Care on February 28, 2025

School Name	School Identifier	Testing information					Result		Public Communication Plan
	Ministry Asset Number	Test Date (dd-mm-yyy)	Time of test (24hr clock)	Sample Type	Fixture Type	Fixture Location Description	Lead Result (mg/L)	Exceeds Maximum Acceptable Concentration	
Shoreline Middle	6161058	21/01/2025	09:20:00	First Draw	CF	foodsroom flt# 11	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Shoreline Middle	6161058	21/01/2025	09:20:00	Flushed	CF	foodsroom flt# 11	0.001	No	lead filter installed with lead free fixture,information provided to staff.
Sir James Douglas Elementary	6161007	18/02/2025	09:20:00	First Draw	CF	room# 104	0.0033	No	lead filter installed with lead free fixture,information provided to staff.
Sir James Douglas Elementary	6161007	18/02/2025	09:20:00	Flushed	CF	room# 104	0.0027	No	lead filter installed with lead free fixture,information provided to staff.
Sir James Douglas Elementary	6161007	18/02/2025	09:30:00	First Draw	CF	room# 203	0.0034	No	lead filter installed with lead free fixture,information provided to staff.
Sir James Douglas Elementary	6161007	18/02/2025	09:30:00	Flushed	CF	room# 203	0.0045	No	lead filter installed with lead free fixture,information provided to staff.
Sir James Douglas Elementary	6161007	18/02/2025	09:40:00	First Draw	CF	room# 107	0.0011	No	lead filter installed with lead free fixture,information provided to staff.
Sir James Douglas Elementary	6161007	18/02/2025	09:40:00	Flushed	CF	room# 107	0.0037	No	lead filter installed with lead free fixture,information provided to staff.
Sir James Douglas Elementary	6161007	18/02/2025	09:50:00	First Draw	CF	room# 113	0.0026	No	lead filter installed with lead free fixture,information provided to staff.
Sir James Douglas Elementary	6161007	18/02/2025	09:50:00	Flushed	CF	room# 113	0.0028	No	lead filter installed with lead free fixture,information provided to staff.
Sir James Douglas Elementary	6161007	18/02/2025	10:00:00	First Draw	CF	room# 115	0.0038	No	lead filter installed with lead free fixture,information provided to staff.
Sir James Douglas Elementary	6161007	18/02/2025	10:00:00	Flushed	CF	room# 115	0.0038	No	lead filter installed with lead free fixture,information provided to staff.
Sir James Douglas Elementary	6161007	18/02/2025	10:05:00	First Draw	CF	room# 118	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Sir James Douglas Elementary	6161007	18/02/2025	10:05:00	Flushed	CF	room# 118	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
SJ Burnside	6161000	11/02/2025	07:00:00	First Draw	KC	foodsroom flt# 5	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
SJ Burnside	6161000	11/02/2025	07:00:00	Flushed	KC	foodsroom flt# 5	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
SJ Burnside	6161000	11/02/2025	07:05:00	First Draw	KC	foodsroom flt# 6	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
SJ Burnside	6161000	11/02/2025	07:05:00	Flushed	KC	foodsroom flt# 6	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
SJ Burnside	6161000	11/02/2025	07:10:00	First Draw	KC	foodsroom flt# 7	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
SJ Burnside	6161000	11/02/2025	07:10:00	Flushed	KC	foodsroom flt# 7	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
SJ Burnside	6161000	22/02/2025	12:30:00	First Draw	KC	kitchen 1001	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
SJ Burnside	6161000	22/02/2025	12:30:00	Flushed	KC	kitchen 1001	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
SJ Willis	6199033	19/02/2025	08:30:00	First Draw	KC	foodsroom flt# 11	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
SJ Willis	6199033	19/02/2025	08:30:00	Flushed	KC	foodsroom flt# 11	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
SJ Willis	6199033	19/02/2025	08:35:00	First Draw	KC	foodsroom flt# 12	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
SJ Willis	6199033	19/02/2025	08:35:00	Flushed	KC	foodsroom flt# 12	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
SJ Willis	6199033	19/02/2025	08:40:00	First Draw	KC	foodsroom flt# 13	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
SJ Willis	6199033	19/02/2025	08:40:00	Flushed	KC	foodsroom flt# 13	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
SJ Willis	6199033	19/02/2025	08:45:00	First Draw	KC	foodsroom flt# 14	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
SJ Willis	6199033	19/02/2025	08:45:00	Flushed	KC	foodsroom flt# 14	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
SJ Willis	6199033	19/02/2025	08:50:00	First Draw	KC	foodsroom flt# 15	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
SJ Willis	6199033	19/02/2025	08:50:00	Flushed	KC	foodsroom flt# 15	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
SJ Willis	6199033	19/02/2025	08:55:00	First Draw	KC	foodsroom flt# 16	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
SJ Willis	6199033	19/02/2025	08:55:00	Flushed	KC	foodsroom flt# 16	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
SJ Willis	6199033	19/02/2025	09:00:00	First Draw	KC	foodsroom flt# 17	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
SJ Willis	6199033	19/02/2025	09:00:00	Flushed	KC	foodsroom flt# 17	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
South Park Elementary	6161002	18/02/2025	08:20:00	First Draw	BS	hallway 1007	0.0007	No	lead filter installed with lead free fixture,information provided to staff.
South Park Elementary	6161002	18/02/2025	08:20:00	Flushed	BS	hallway 1007	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
South Park Elementary	6161002	18/02/2025	08:30:00	First Draw	KC	staff room	0.001	No	lead filter installed with lead free fixture,information provided to staff.
South Park Elementary	6161002	18/02/2025	08:30:00	Flushed	KC	staff room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
South Park Elementary	6161002	18/02/2025	08:40:00	First Draw	KC	pac kitchen	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
South Park Elementary	6161002	18/02/2025	08:40:00	Flushed	KC	pac kitchen	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
South Park Elementary	6161002	18/02/2025	08:50:00	First Draw	CF	room 208	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
South Park Elementary	6161002	18/02/2025	08:50:00	Flushed	CF	room 208	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	14/02/2025	11:00:00	First Draw	CF	room 1022	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	14/02/2025	11:00:00	Flushed	CF	room 1022	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	14/02/2025	11:05:00	First Draw	KC	foodsroom flt# 4	0.0006	No	lead filter installed with lead free fixture,information provided to staff.

Greater Victoria School District
Annual Water Sampling Report
Submitted to Ministry of Education and Child Care on February 28, 2025

School Name	School Identifier	Testing information					Result		Public Communication Plan
	Ministry Asset Number	Test Date (dd-mm-yyy)	Time of test (24hr clock)	Sample Type	Fixture Type	Fixture Location Description	Lead Result (mg/L)	Exceeds Maximum Acceptable Concentration	
Spectrum Community	6161063	14/02/2025	11:05:00	Flushed	KC	foodsroom ftl# 4	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	14/02/2025	11:10:00	First Draw	KC	foodsroom ftl# 5	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	14/02/2025	11:10:00	Flushed	KC	foodsroom ftl# 5	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	14/02/2025	11:15:00	First Draw	KC	foodsroom ftl# 6	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	14/02/2025	11:15:00	Flushed	KC	foodsroom ftl# 6	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	14/02/2025	11:20:00	First Draw	KC	foodsroom ftl# 7	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	14/02/2025	11:20:00	Flushed	KC	foodsroom ftl# 7	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	14/02/2025	11:30:00	First Draw	KC	foodsroom ftl# 8	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	14/02/2025	11:30:00	Flushed	KC	foodsroom ftl# 8	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	14/02/2025	11:35:00	First Draw	KC	foodsroom ftl# 9	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	14/02/2025	11:35:00	Flushed	KC	foodsroom ftl# 9	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	14/02/2025	11:40:00	First Draw	KC	foodsroom ftl# 10	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	14/02/2025	11:40:00	Flushed	KC	foodsroom ftl# 10	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	14/02/2025	11:45:00	First Draw	KC	foodsroom ftl# 12	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	14/02/2025	11:45:00	Flushed	KC	foodsroom ftl# 12	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	14/02/2025	11:50:00	First Draw	KC	foodsroom ftl# 15	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	14/02/2025	11:50:00	Flushed	KC	foodsroom ftl# 15	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	14/02/2025	11:55:00	First Draw	KC	foodsroom ftl# 16	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	14/02/2025	11:55:00	Flushed	KC	foodsroom ftl# 16	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	22/02/2025	13:08:00	First Draw	KC	room 0040	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	22/02/2025	13:08:00	Flushed	KC	room 0040	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	22/02/2025	13:14:00	First Draw	KC	room 0036	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Spectrum Community	6161063	22/02/2025	13:14:00	Flushed	KC	room 0036	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Strawberry Vale Elementary	6161032	19/02/2025	14:10:00	First Draw	KC	red barn daycare	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Strawberry Vale Elementary	6161032	19/02/2025	14:10:00	Flushed	KC	red barn daycare	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Strawberry Vale Elementary	6161032	19/02/2025	12:50:00	First Draw	BS	outside room 105	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Strawberry Vale Elementary	6161032	19/02/2025	12:50:00	Flushed	BS	outside room 105	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Strawberry Vale Elementary	6161032	19/02/2025	13:00:00	First Draw	BS	outside room 126	0.0012	No	lead filter installed with lead free fixture,information provided to staff.
Strawberry Vale Elementary	6161032	19/02/2025	13:00:00	Flushed	BS	outside room 126	0.0007	No	lead filter installed with lead free fixture,information provided to staff.
Strawberry Vale Elementary	6161032	19/02/2025	13:10:00	First Draw	BS	outside gym	0.0021	No	lead filter installed with lead free fixture,information provided to staff.
Strawberry Vale Elementary	6161032	19/02/2025	13:10:00	Flushed	BS	outside gym	0.0015	No	lead filter installed with lead free fixture,information provided to staff.
Strawberry Vale Elementary	6161032	19/02/2025	13:20:00	First Draw	KC	room 150	0.0007	No	lead filter installed with lead free fixture,information provided to staff.
Strawberry Vale Elementary	6161032	19/02/2025	13:20:00	Flushed	KC	room 150	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Sundance-Bank Elementary	6161008	24/01/2025	09:00:00	First Draw	BS	outside room 102	0.0013	No	lead filter installed with lead free fixture,information provided to staff.
Sundance-Bank Elementary	6161008	24/01/2025	09:00:00	Flushed	BS	outside room 102	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Sundance-Bank Elementary	6161008	24/01/2025	09:05:00	First Draw	BS	outside room 1003	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Sundance-Bank Elementary	6161008	24/01/2025	09:05:00	Flushed	BS	outside room 1003	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Sundance-Bank Elementary	6161008	24/01/2025	09:10:00	First Draw	BS	outside room 2003	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Sundance-Bank Elementary	6161008	24/01/2025	09:10:00	Flushed	BS	outside room 2003	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Sundance-Bank Elementary	6161008	24/01/2025	09:15:00	First Draw	KC	staff room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Sundance-Bank Elementary	6161008	24/01/2025	09:15:00	Flushed	KC	staff room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Tillicum Elementary	6161020	29/01/2025	07:00:00	First Draw	KC	OSC 1	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Tillicum Elementary	6161020	29/01/2025	07:00:00	Flushed	KC	OSC 1	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Tillicum Elementary	6161020	29/01/2025	07:05:00	First Draw	KC	OSC 2	0.0011	No	lead filter installed with lead free fixture,information provided to staff.
Tillicum Elementary	6161020	29/01/2025	07:05:00	Flushed	KC	OSC 2	0.0007	No	lead filter installed with lead free fixture,information provided to staff.
Tillicum Elementary	6161020	29/01/2025	07:10:00	First Draw	BS	hallway 1021	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Tillicum Elementary	6161020	29/01/2025	07:10:00	Flushed	BS	hallway 1021	0.0006	No	lead filter installed with lead free fixture,information provided to staff.

Greater Victoria School District
Annual Water Sampling Report
Submitted to Ministry of Education and Child Care on February 28, 2025

School Name	School Identifier	Testing information					Result		Public Communication Plan
	Ministry Asset Number	Test Date (dd-mm-yyy)	Time of test (24hr clock)	Sample Type	Fixture Type	Fixture Location Description	Lead Result (mg/L)	Exceeds Maximum Acceptable Concentration	
Tillicum Elementary	6161020	29/01/2025	07:15:00	First Draw	BS	hallway 1057	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Tillicum Elementary	6161020	29/01/2025	07:15:00	Flushed	BS	hallway 1057	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Torquay Elementary	6161065	18/02/2025	07:50:00	First Draw	KC	med room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Torquay Elementary	6161065	18/02/2025	07:50:00	Flushed	KC	med room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Torquay Elementary	6161065	18/02/2025	07:55:00	First Draw	KC	staff room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Torquay Elementary	6161065	18/02/2025	07:55:00	Flushed	KC	staff room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victor School	6161006	14/02/2025	07:35:00	First Draw	CF	room# 1	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victor School	6161006	14/02/2025	07:35:00	Flushed	CF	room# 1	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victor School	6161006	14/02/2025	07:40:00	First Draw	CF	room# 3	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victor School	6161006	14/02/2025	07:40:00	Flushed	CF	room# 3	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victor School	6161006	14/02/2025	07:45:00	First Draw	BS	outside room# 3	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victor School	6161006	14/02/2025	07:45:00	Flushed	BS	outside room# 3	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victor School	6161006	14/02/2025	07:50:00	First Draw	CF	room 4	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victor School	6161006	14/02/2025	07:50:00	Flushed	CF	room 4	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria High	6161018	02/11/2025	13:20:00	First Draw	KC	foodsroom ftl# 13	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria High	6161018	02/11/2025	13:20:00	Flushed	KC	foodsroom ftl# 13	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria High	6161018	02/11/2025	13:25:00	First Draw	KC	foodsroom ftl# 14	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria High	6161018	02/11/2025	13:25:00	Flushed	KC	foodsroom ftl# 14	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria High	6161018	02/11/2025	13:30:00	First Draw	KC	foodsroom ftl# 15	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria High	6161018	02/11/2025	13:30:00	Flushed	KC	foodsroom ftl# 15	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria High	6161018	02/11/2025	13:35:00	First Draw	KC	foodsroom ftl# 16	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria High	6161018	02/11/2025	13:35:00	Flushed	KC	foodsroom ftl# 16	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria High	6161018	02/11/2025	13:40:00	First Draw	KC	foodsroom ftl# 17	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria High	6161018	02/11/2025	13:40:00	Flushed	KC	foodsroom ftl# 17	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria High	6161018	02/11/2025	13:50:00	First Draw	KC	foodsroom ftl# 18	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria High	6161018	02/11/2025	13:50:00	Flushed	KC	foodsroom ftl# 18	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria High	6161018	02/11/2025	13:55:00	First Draw	KC	foodsroom ftl# 19	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria High	6161018	02/11/2025	13:55:00	Flushed	KC	foodsroom ftl# 19	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria High	6161018	24/02/2025	08:15:00	First Draw	BS	hallway 1057	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria High	6161018	24/02/2025	08:15:00	Flushed	BS	hallway 1057	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria High	6161018	24/02/2025	08:20:00	First Draw	BS	hallway 1052	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria High	6161018	24/02/2025	08:20:00	Flushed	BS	hallway 1052	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria West Elementary	6161004	29/01/2025	11:25:00	First Draw	KC	OSC 1	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria West Elementary	6161004	29/01/2025	11:25:00	Flushed	KC	OSC 1	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria West Elementary	6161004	29/01/2025	11:30:00	First Draw	KC	OSC 2	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria West Elementary	6161004	29/01/2025	11:30:00	Flushed	KC	OSC 2	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria West Elementary	6161004	29/01/2025	11:35:00	First Draw	KC	med room	0.0008	No	lead filter installed with lead free fixture,information provided to staff.
Victoria West Elementary	6161004	29/01/2025	11:35:00	Flushed	KC	med room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria West Elementary	6161004	29/01/2025	11:40:00	First Draw	KC	staff room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria West Elementary	6161004	29/01/2025	11:40:00	Flushed	KC	staff room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria West Elementary	6161004	29/01/2025	11:45:00	First Draw	BS	outside room 15	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Victoria West Elementary	6161004	29/01/2025	11:45:00	Flushed	BS	outside room 15	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
View Royal Elementary	6161029	29/01/2025	10:20:00	First Draw	KC	OSC ftl # 1	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
View Royal Elementary	6161029	29/01/2025	10:20:00	Flushed	KC	OSC ftl # 1	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
View Royal Elementary	6161029	29/01/2025	10:30:00	First Draw	KC	OSC ftl # 2	0.0017	No	lead filter installed with lead free fixture,information provided to staff.
View Royal Elementary	6161029	29/01/2025	10:30:00	Flushed	KC	OSC ftl # 2	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
View Royal Elementary	6161029	29/01/2025	10:35:00	First Draw	KC	OSC ftl # 8	0.0006	No	lead filter installed with lead free fixture,information provided to staff.

Greater Victoria School District
Annual Water Sampling Report
Submitted to Ministry of Education and Child Care on February 28, 2025

School Name	School Identifier	Testing information					Result		Public Communication Plan
	Ministry Asset Number	Test Date (dd-mm-yyy)	Time of test (24hr clock)	Sample Type	Fixture Type	Fixture Location Description	Lead Result (mg/L)	Exceeds Maximum Acceptable Concentration	
View Royal Elementary	6161029	29/01/2025	10:35:00	Flushed	KC	OSC ftl # 8	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
View Royal Elementary	6161029	29/01/2025	10:50:00	First Draw	BS	hallway 1019	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
View Royal Elementary	6161029	29/01/2025	10:50:00	Flushed	BS	hallway 1019	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
View Royal Elementary	6161029	29/01/2025	10:55:00	First Draw	CF	room 22	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
View Royal Elementary	6161029	29/01/2025	10:55:00	Flushed	CF	room 22	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Uplands Campus	6161044	24/01/2025	08:10:00	First Draw	BS	hallway 1030	0.0011	No	lead filter installed with lead free fixture,information provided to staff.
Uplands Campus	6161044	24/01/2025	08:10:00	Flushed	BS	hallway 1030	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Uplands Campus	6161044	24/01/2025	08:15:00	First Draw	KC	staff room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.
Uplands Campus	6161044	24/01/2025	08:15:00	Flushed	KC	staff room	0.0006	No	lead filter installed with lead free fixture,information provided to staff.